

Ref: BHE/PW/PUR/TLRPT-FGD-BOP-CVL/2944/Corg 03

Dt: 08/05/2024

Page 1 of 2

ALL BIDDERS

**Sub: Corrigendum-03: Clarification**

**Job:** Civil and Architectural Works of FGD, GHP, LHP RCC-Structures and Buildings and BOP Buildings of Raw-Water Pump House, Raw Water Booster Pump House, MCC & IO Room, CW Treatment Plant, CW- Chlorination Plant, CW Pipe -1 & 2 encasing from transformer yard upto CW Pump House & upto NDCT-1 & 2, Respective Pipe & Cable rack, Pipe Pedestals, Sleepers, Leveling & Grading and Other Miscellaneous Foundations at 2x660 MW NTPC Talcher

Tender Specification Number: BHE/PW/PUR/TLRPT-FGD-BOP-CVL/2944

NIC Tender ID: 2024\_BHEL\_35062\_1

Bidders to kindly take note of the following:

**AA) Bidders to take note of the following clarification:**

Sl. no	Reference clause of Tender Document	Existing provision	Bidder's query	BHEL's Reply
1	Chapter-IV: T&Ps and MMEs to be deployed by Contractor <b>4.0 Tools and Plants:</b>	Concrete Batching Plant (30 Cum/Hr.) with three (03) Nos. of Silos of 100 MT capacity each for cement and one additional silo of 100MT capacity fly ash 01 Set	With reference to above tender please clarify that we are interested to tie up for RMC SUPPLY from third party / available party for RMC / Batching Plant As per requirement at TALCHER POWER STATION. Please confirm.	<b>Modified Clause:-</b> Instead of existing provision as mentioned in TCC, Agency may tie up for batching plant with available party/ Batching Plant and will furnish the documents of agreements between both the parties, all statutory compliances like royalty, gate passes, labour licenses etc. shall in the name of bidder. Bidder has to ensure the uninterrupted supply of RMC during the entire work period (including extended period), In the event of failure of getting supply from the tied up party, BHEL reserve the rights for supply of RMC by making alternative arrangement and recover the cost incurred for the same along with 5% overheads. Also at any stage of work if work affected due to non-availability of RMC BHEL may ask the bidder to install the separate batching plant and to mobilize associated T & P. <b>Note: Agency can use Either Existing provision of TCC or modified clause as mentioned above.</b>

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.



Ref: BHE/PW/PUR/TLRPT-FGD-BOP-CVL/2944/Corg 03

Dt: 08/05/2024

-----Page 2 of 2-----

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum/ digitally signed.

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,  
Yours Sincerely,

(Purchase)