

To,

ALL BIDDERS

Subject: **Corrigendum-03:** Amendment to TCC and Clarification to Bidder's queries.

Tender Specification No: **BHE/PW/PUR/KNFGD-MECH-E&C/Common Systems/2603**

Job Description: Handling of materials at BHEL / Client's Stores / Storage Yard and transportation to site, Erection, Testing, Assistance for commissioning including supply & application of final painting of Limestone handling System, Gypsum handling System and other Common Systems Including Fabrication & Erection of Limestone Storage Silo of Stage I, II & III Flue Gas Desulphurization System (FGD)

at

3x200MW + 3x500MW + 1x500MW, Stage- I, II & III NTPC Korba FGD Project

Bidders to kindly take note of the following:

=====

AA) Clause No. 5.16 of Chapter V (T&Ps and MMEs to be Provided by BHEL) of Vol IA NIT and TCC at Page No. 90 of 188 stands **deleted**.

BB) Clause No. 13.67.2 (Buried Piping) of Chapter-XIII Erection of Vol IA NIT and TCC at Page No. 152-153 of 188 stands **deleted**.

CC) ISSUE OF CLARIFICATIONS w.r.t Bidder's queries

<u>Reference Clause of Tender Document</u>	<u>Bidder's Query</u>	<u>BHEL's Clarification</u>
VOL_I_NIT_TCC (Chapter-XII Civil Works, Foundation, Grouting; Clause No.: 12.3 at Page no. 130 of 188)	Kindly provide Scope of Grouting Area & Qty	Grouting to be done where any mechanical structure/equipment is fixed in civil foundation. List of structures and equipment provided in BOQ
VOL_I_NIT_TCC (Chapter – II: Scope of Work and Technical Specifications; Clause No.: 2.26.22 at Page no. 65 of 188)	Kindly clarify scope of Supply of SS plate for Liner Works	Supply of stainless steel liner of grade SS:409M is in scope of BHEL. Applicable elsewhere also in the tender documents (i.e. Chapter IX, page 104, sl no 12 and Chapter XIX, Page 183 Sl no b)

<u>Reference Clause of Tender Document</u>	<u>Bidder's Query</u>	<u>BHEL's Clarification</u>
VOL_I_NIT_TCC (Chapter-XIV FABRICATION & ERECTION OF STRUCTURAL STEEL; Clause No.: 14.4.12 at Page no. 160 of 188)	Kindly clarify scope of Steel Plate for Welder qualification Test piece	Test piece is in the scope of bidder

****Note:** In the event of any ambiguity or conflict between the Corrigendum-03 issued wrt the clauses of NIT & GCC, Corrigendum-03 shall prevail.*

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → <https://eprocurebhel.co.in>

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours Sincerely,

GM (Purchase)