

Ref: BHE/PW/PUR/WNT-DM PLANT PGTEST-U8/2402/Corg-03/Clarifications Dt: 12/04/2021
 -----Page 1 of 2-----

To,

ALL BIDDERS,

Sub: Corrigendum-03: Clarifications and Time Extn

Job: Resolution of pending technical issues and Expert/ Consulting services for DM Plant PG test at Wanakbori Extn Unit-08 Set-01 at GSECL 1X800MW project.

E- TENDER SPECIFICATION NUMBER: BHE/PW/PUR/WNT-DM PLANT PGTEST-U8/2402

Bidders to kindly take note of the following:

AA) Clarifications:

SI no.	Bidder's query	BHEL's Clarifications
1	Resin will be provided by M/s BHEL.	Already mentioned in Cl no. 07 of 'A. Special condition of contract' of Chap.II of TCC. (Pg no. 50/64)
2	Resin Loading / Unloading by M/s BHEL.	Already mentioned in Cl no. 06 of 'A. Special condition of contract' of Chap.II of TCC. (Pg no. 50/64)
3	Pall Ring Loading / Unloading by M/s BHEL.	Yes. In line with Cl no. 06 of 'A. Special condition of contract' of Chap.II of TCC. (Pg no. 50/64)
4	All non -working Instruments (FT/FI / PT/PI / Analysers pH/Conductivity / Sodium/ Silica/ Turbidity) & Auto valves to be properly operational by M/s BHEL before PGTR.	Yes. In line with Cl no. 05 of 'A. Special condition of contract' of Chap.II of TCC. (Pg no. 50/64)
5	All water sampling to be done in the Inhouse facility of M/s BHEL during PGTR & Pre PGTR.	Yes. In line with Cl no. 05 of 'A. Special condition of contract' of Chap.II of TCC. (Pg no. 50/64)
6	Ejectors / Pall rings / Mid Collector Nozzles will be supplied by bidder.	Yes. In line with Cl no. 03 and 04 of 'B. Bidder scope of work' of Chap.II of TCC. (Pg no. 50/64)
7	Respective Piping UPVC/CPVC for Installation of Ejectors by bidder.	Yes. In line with Cl no. 03 of 'B. Bidder scope of work' of Chap.II of TCC. (Pg no. 50/64)
8	The performance guarantees of the DM plant design is subject to inlet water quality availability as per the tender. Any deviation of water quality with respect to parameters mentioned in the tender might lead to non-achievement of guaranteed parameters of output water quality.	BHEL has furnished the Water parameter in tender documents. Bidder to follow the tender condition. Tender condition shall prevail.

Ref: BHE/PW/PUR/WNT-DM PLANT PGTEST-U8/2402/Corg-03/Clarifications Dt: 12/04/2021
 -----Page 2 of 2-----

9	As per resin data sheet of DM plant design the linear velocity is 39.8 m/h for SAC & SBA , 52.35 m/h for MB unit. It is higher side of normal DM plant Design, Hence we will try to get a match max output specification of DM plant.	Tender conditions shall prevail.
10	We would like to clarify on PG/SDBG that this contract doesn't involve any design or new fabrication from our site. Any supplies to be done in the contract will be as per the approved drawing & data sheet provided to us by M/s BHEL Hence we would request you to waive off the requirement to submit PG/SDBG.	As per cl 14 of Annexure-12: IMPORTANT INFORMATION of the NIT (Pg no. 44/64) 'Clause no. 2.24 of GCC PERFORMANCE GUARANTEE FOR WORKMANSHIP: Not Applicable'. Security Deposit Applicable as per GCC. ----- Tender conditions shall prevail.

BB) EXTENSION OF LAST DATE OF OFFER SUBMISSION

The last date for submission of Tender has been re-scheduled to 20/04/2021, 11.00 hrs.
 Technical Bid shall be opened on 20/04/2021 at 16:00 hrs

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum03ClarificationsandTimeExtn" against NIT-2402 on **BHEL GeP NIC Portal** i.e. <https://eprocurebhel.co.in>

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN **BHEL GeP NIC Portal** i.e. <https://eprocurebhel.co.in>

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
 Yours faithfully,

AGM (Purchase)