



ISO 9001-2000, ISO 14001, OHSAS 18001 and SA
8000 certified company
Sub-Contract and Purchase Department.

भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

पावर सेक्टर, उ.क्षे.परिसर, प्लॉट नं.25, सेक्टर-16ए, पोस्ट बॉक्स सं.55, नोएडा-201301,
Power Sector-Northern Region, Plot no.25, Sector 16 A PB NO. 55, NOIDA.201301

Ph. : 0120-2416548 / 2416292, Fax 0120-2515464

e-mail: rahuldeb@bhel.in, rajesh.k@bhel.in

CORRIGENDUM – III Dtd: 13.07.2018

Tender Enq. No. BHEL/PSNR/SCP/RD/ E-2954 DATED 09.06.2018

Kindly be informed about the following points regarding above tender:

1. The **PQR Sl. no. A** for Wet Stack Model Study of NIT is hereby modified as:

Sl. No.	Existing Clause	Clause to be Modified as:
A	The bidder should have carried out Wet Stack Flow Study which has successfully performed at least two (2) flow model studies, in separate coal fired power plants, of wet stack installed after wet limestone based FGD Absorber (Without reheating of cleaned flue gas), and based on the studies developed at least two (2) wet stack liquid collection systems which are in successful operation for a period of at least two (2) years reckoned as on the date of consideration for approval	The bidder should have carried out Wet Stack Flow Study of their own or arrange it through suitable agency. Bidder or its agency should have successfully performed at least two (2) flow model studies, in separate coal fired power plants, of wet stack installed after wet limestone based FGD Absorber (Without reheating of cleaned flue gas), and based on the studies developed at least two (2) wet stack liquid collection systems which are in successful operation for a period of at least two (2) years reckoned as on the date of consideration for approval.

2. The due date of opening of the above referred tender is hereby extended to 23.07.2018 (SUBMISSION TIME: 1330 Hrs. & OPENING TIME: 1530 Hrs.).
3. All other terms and conditions of the tender shall remain unchanged.
4. This corrigendum / addendum shall be a part of tender.


Sr. ENGINEER/PURCHASE