



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-18-Feb-22

CORRIGENDUM- 04

PROJECT	:	2x250 MW NSPCL BHILAI TPP-FGD
PACKAGE	:	GYPSUM DEWATERING SYSTEM (VACUUM BELT FILTER TYPE)
ENQUIRY NO	:	PE/PG/BLI/E-6839/2021 dated. 10.01.2022
SUBJECT	:	Pre-Bid clarifications

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

In reference to the above mentioned tender enquiry please note the following.

S. NO.	SECTION	CLAUSE	PAGE NO.	STATEMENT OF THE REFERRED CLAUSE	CLARIFICATION REQUIRED by bidder	BHEL Reply
1	Tendernotice_9	2.b	392 of 420	Mandatory spares list 2,b) Belt - 1 Set	Clause no 4.3.3 is referring to Filter cloth not for Wear belt/Sealing belt. for clause no 2.b mandatory spare – Belt- 1 Set applicable section is 4.3.5 of page no 47 of 528. Bidder shall consider Sealing belt/wear belt as spare, indicative life of the these belts are 1800 Hrs. Bidder shall be providing indicative life of Sealing Belt for 7000 Hrs for the First installation (along with machine only) i.e. cumulative hours (for example: if one Sealing Belt operates for 5000 Hrs and we shall provide another Sealing Belt to complete the 7000 hours if necessary).	Bidder to follow Tender specification. All applicable belts are to be supplied against clause no. 2.b (of Annexure II -Mandatory spare list, page 392 of 528 of tender specification) as mandatory spare.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to participate accordingly.

Yours faithfully,

For and on behalf of BHEL

Vinit Kumar Verma
Manager