



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-12-Dec-22

CORRIGENDUM- 04

PROJECTs	:	2 x 660 MW NTPC TALCHER TPP, STAGE - III
PACKAGE	:	PRE TREATMENT PLANT
ENQUIRY NO	:	PE/PG/HER/E-7110/2022 Dated 22.11.2022
SUBJECT	:	PRE-BID CLARIFICATION + DUE DATE EXTENSION

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input checked="" type="checkbox"/>

Bidders are requested to go through the following -

1. Refer attached BHEL replies to Pre-Bid Bid Queries.
2. Due date & time of bid submission has been extended upto 19.12.2022 @11:00 AM. Bid opening shall be done at 04:00 PM on the due date.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Manager/BOP

BHEL Replies to Pre-bid Queries

S.No.	Volume	Section	Clause No.	Page No.	Specification Requirement	Clarification	Reasons for Clarification	BHEL Reply
1.	VOLUME – II B & III	SECTION-C1 (SPECIFIC TECHNICAL REQUIRMENT MECHANICAL)	3.0 SCOPE OF SUPPLY (MECHANICAL)- & P&ID	23 & 243	Length of Sludge Pipe	Sludge Discharge Pipe Length from Sludge Pit to Ash Slurry Sump is not mentioned. Please provide: 1) Length of Pipe OR distance from Sludge pit to Ash slurry Sump 2) Discharge Head of Sludge Transfer Pump	Technical	Bidder to refer S.No. 69 (d)/Page 25 of 714 in the tender specification. Further bidder to select discharge head of pump considering tender specification requirement accordingly.