

Ref: BHE/PW/PUR/RGFGD-BAL-MECH/3020/Corg 04:Clarification

Dt: 13/09/2024

-----Page 1 of 2-----

ALL BIDDERS

Sub: Corrigendum-04: Clarification

Job: Handling of materials at BHEL / Client's Stores / Storage Yard and transportation to site Erection, Testing, Assistance for commissioning & Trial Operation including supply & application of final painting and Handing Over of **Flue Gas Desulphurization System (FGD)** Erection and Commissioning of Balance Mechanical Works **AT 3x200MW + 3X500 MW NTPC Ramagundam, Stage- I & II, Telangana**

Tender Specification Number: BHE/PW/PUR/RGFGD-BAL-MECH/3020

NIC Tender ID: 2024_BHEL_39298_1

Bidders to kindly take note of the following:

AA) Bidders to take note of the following clarification:

SI No	Reference Clause of Tender Document	Existing Provision	Bidders Query	BHEL's clarification
1	SL.No 2 of Chapter IV Page no 75 of 150	Tyre mounted / mobile crane (Telescopic boom, Hydraulically operated with turret function) - 1 no MIN	Telescopic boom crane of these specifications are not possible to be deployed with in this short tenure. Request to be excluded from our scope.	Tyre Mounted Crane/mobile crane of capacity >= 60 MT and <=100 MT shall be in the scope of Agency.
2	SL.No 62 of Chapter IV Page no 78 of 150	Man lifter for bolted structure bolt tightening - Min 120ft boom	At least 1 no Man lifter can be excluded from our scope.	Tender conditions shall prevail
3	Chapter-IX: ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE OF WORK (BOQ) AND Chapter – II: Scope of Work	Quantities in BOQ are mentioned in Package A and Package B	Quantities in BOQ are to be clarified in Package A and Package B are required to be mentioned Unit wise and Area wise as most of the works are found incomplete in all Units 4, 5, 6 at site.	Package A & Package B has been separated to calculate the R&C of the existing agencies. Work involves Absorber of Unit 5, Common System and Structural and piping works of all 3 units.



Ref: BHE/PW/PUR/RGFGD-BAL-MECH/3020/Corg 04:Clarification

Dt: 13/09/2024

-----Page 2 of 2-----

SI No	Reference Clause of Tender Document	Existing Provision	Bidders Query	BHEL's clarification
4	Structure	Structure	Structure works in all the Units were executed at site and Major members were also erected. Area wise and Unit wise bifurcation is required.	Structure works of Unit 4, 5 & 6 are included in the scope of work. Agency to visit site to take actual condition of sites.
5	Non-Pressure Parts Including Tanks	Non Pressure Parts Including Tanks	In case of FGD absorber system, which Unit is considered in the BOQ has to be clarified.	Absorber of only Unit 5 is included.
6	Rotating Machines	Rotating Machines	Rotating machines of which Unit is considered in the BOQ has to be clarified.	Rotating Machines of Unit 4, 5 & 6 and common systems are included.
5	Non Pressure Parts Including Tanks	Non Pressure Parts Including Tanks	In case of FGD absorber system, which Unit is considered in the BOQ has to be clarified.	Absorber of only Unit 5 is included.

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum/ digitally signed.

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours Sincerely,

(Purchase)