



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-21-Nov-22

CORRIGENDUM- 05

PROJECT	:	3×800 MW PVUNL PATRATU TPP Phase-I
PACKAGE	:	COAL HANDLING PLANT RUN-OFF WATER TREATMENT SYSTEM
ENQUIRY NO	:	E-7090/2022 Dated. 20.10.2022
SUBJECT	:	PRE- BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

Please note the following:

Pre-Bid Clarification attached with this corrigendum shall be treated as part of NIT.

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

**Sharad Chandra
Manager/BOP**

S.No.	Volume	Section	Clause No.	Page No.	Specification Requirement	Clarification	Reasons for Clarification	BHEL Reply
1.	-	-	-	-	-	For the Additional piping mentioned in E-70902022TECHSPEC, Section 4 Piping in page 26 of 538, Bidder's scope shall be limited to only supply of the Pipe, Fittings, Welding, Internal & External protection as Civil works are part of BHEL's scope.	-	Please refer the technical specification clause No.4.0 and subsequent corrigenda-II in this regard. As per tender specification & corrigenda-II requirement the pipes are to be designed, supplied, erected, laid and tested by the bidder. However, as all the civil work is excluded from bidder's scope and hence any civil work (i.e. excavation, backfilling, pedestal as required) shall be part of civil work activity by BHEL.
2.	-	-	-	-	-	The Civil works comprising of Statutory approval, Road crossings, Trenchless Ground excavation, Bottom / Top Levelling, Leading & laying of pipe works as applicable shall be part of BHEL.	-	Noted.