

Ref: BHE/PW/PUR/2106057/Corg-06, Date: 17/07/2021

-----Page 1 of 2-----

To
ALL BIDDERS,

Sub: Corrigendum-06: Clarification to bidder's query & Amendment to Tender specification document

Reference:

1. **E-Tender Specification. No:** 2106057

2. **Scope of work:** Design, manufacture, assembly, inspection & testing at vendor's/ sub-vendor's works, proper packing and delivery to site, Erection & Commissioning of LIGHTING FIXTURES, LAMPS & MISCELLANEOUS ITEMS as mentioned in different sections of this specification, complete with all accessories for efficient and trouble-free operation for Owner's Office and Owner's Storage at 3x800MW PVUNL Patratu Project.

Corrigendum Ref: -

Sl. No.	Corrigendum Ref	Corrigendum Type
1	Corrigendum-01	Time extension
2	Corrigendum-02	Amendment to Tender document
3	Corrigendum-03	Time extension
4	Corrigendum-04	Clarification to bidder's query & Amendment to Tender document
5	Corrigendum-05	Time extension

Bidders to kindly take note of the following:

AA) Clarifications to Pre-Bid Queries by bidders & Amendment to the tender conditions

S. No.	Cl. Of Tender Specification	Description	Bidder's Query	BHEL Clarifications/ Amendment to the tender conditions
1	BOQ Sl. No. 8.4 to 8.8	-	Please provide the size and specification of LAN &	List of approved Suppliers for cables (BOQ Sl.

Ref: BHE/PW/PUR/2106057/Corg-06, Date: 17/07/2021

Page 2 of 2

S. No.	Cl. Of Tender Specification	Description	Bidder's Query	BHEL Clarifications/ Amendment to the tender conditions
			Telephone cable. Please note that the quantities of all types/ size of cables i.e. from sr. no. 8.4 to 8.7 are less and no manufacturer will provide the inspection for the same so request you please provide the inspection waiver for the same."	No. 8.6 & 8.7) and New Inspection category for BOQ Sl. NO. 8.4 to 8.8 enclosed herewith as "Annexure-I" for compliance.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL→
<https://eprocurebhel.co.in>

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

GM (Purchase)

LIST OF SUB-SUPPLIERS OF 1.1kV POWER CABLE (PVC & XLPE) FOR 3x800MW PVUNL PATRATU PROJECT

Sub-Package: HT Power Cables, LT Power Cables, LT Control Cables.

S. No. NO.	ITEM	SUB-SUPPLIERS	PLACE
1	1.1kV Power Cable (PVC & XLPE)	CMI Energy India Pvt Ltd	Solan
		Kei Industries	Bhiwadi
		Delton Cable Ltd	Faridabad
		Paramount Cable	Khushkhera
		Polycab Wires Pvt. Ltd.	Daman
		Gemscab Industries	Bhiwadi
		Cords Cables	Bhiwadi
		Havells India Ltd.	Alwar
		Sri Ram Cables	Bhiwadi
		Ravin Cables	Pune
		Thermocables	Hyderabad
		Suyog Cables	Halol
		Gupta Power Cables	Bhubaneshwar
		Special Cables	Rudrapur
		Goyolene Fibre	Silvassa

ILLUMINATION ITEMS FOR OWNER'S OFFICE AND OWNER'S STORAGE (3x800MW PVUNL PATRATU PROJECT)

BOQ Ref No.	Item Description	Inspection Status
8.4	LAN Cable	CAT-III
8.5	Telephone Cable	CAT-III
8.6	LP Incoming Cable 3.5Cx25sqmm AL Unarmoured PVC Insulated Cable	CAT-III (cable to be procured from attached approved make only)
8.7	LP Incoming Cable 3.5Cx50sqmm AL Unarmoured PVC Insulated Cable	CAT-III (cable to be procured from attached approved make only)
8.8	14 SWG GI wire (Earthing)	CAT-III

NOTE:
CAT-III category means the manufacturer's internal test documents of these items shall be reviewed without any physical inspection to be carried out before MDCC.