

Ref: BHE/PW/PUR/KNFGD-CHIMNEY-PKG-C-U-6/2404/PKG-D-U-7/2405/Corg-06

Date: 13/05/2021

To,

ALL BIDDERS,

**Sub:** Corrigendum-06: Issuance of Clarifications and Extension of offer submission due date.

PACKAGE-C: CIVIL AND STRUCTURAL WORKS OF 150M RCC SINGLE FLUE CHIMNEY OF UNIT-6 AT NTPC KORBA STAGE-II (3X500MW) FGD PACKAGE.

AND

PACKAGE-D: CIVIL AND STRUCTURAL WORKS OF 150M RCC SINGLE FLUE CHIMNEY OF UNIT-7 AT NTPC KORBA STAGE-III (1X500MW) FGD PACKAGE.

| S. No. | Package   | E- TENDER SPECIFICATION NUMBER          |
|--------|-----------|-----------------------------------------|
| 01     | Package-C | BHE/PW/PUR/KNFGD-CHIMNEY-PKG-C-U-6/2404 |
| 02     | Package-D | BHE/PW/PUR/KNFGD-CHIMNEY-PKG-D-U-7/2305 |

**Bidders kindly to take note of the following:**

#### AA) Issuance of Clarifications:

| Sr. No. | Documents Reference          | Subject                                                                                       | Tender Terms & Condition                                                       | Bidders' Deviation/ Query                                                                                                                                                                                                                                                                                                                                                                                                                        | BHEL REPLY'S                                                                                                              |
|---------|------------------------------|-----------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------|
| 1       | BOQ - Section C:- Flue Works | Sr. No. C4005; Design, supply and installation of borosilicate glass block lining system----- | Design, supply and installation of borosilicate glass block lining system----- | Please correct description as given below:-<br>Design, supply and installation of borosilicate glass block lining system-----<br>Please also mentioned that adhesive, primer will be free issued by BHEL in BOQ.<br>Please also clarify that Electric Mixing machine should be provide free of cost or not by BHEL.<br><b>BHEL Reply vide corrigendum-04:</b> Please refer scope of work. Only Borosilicate glass supply shall be in BHEL scope. | Only Borosilicate glass shall be supplied by BHEL at free of cost. Rest tender specifications/c onditions shall prevails. |

Ref: BHE/PW/PUR/KNFGD-CHIMNEY-PKG-C-U-6/2404/PKG-D-U-7/2405/Corg-06

Date: 13/05/2021

| Sr. No. | Documents Reference | Subject | Tender Terms & Condition | Bidders' Deviation/ Query                                                                                                                                                                                                                                                                                                                                                                                                                                                                     | BHEL REPLY'S |
|---------|---------------------|---------|--------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|
|         |                     |         |                          | <p><b>Bidders Query:</b></p> <p>Please note that following is not in <b>Bidder Scope of work</b> for Borosilicate Glass Block lining system:</p> <ol style="list-style-type: none"> <li>1. <b>Design</b></li> <li>2. <b>Supply of Borosilicate Glass Blocks</b></li> <li>3. <b>Supply of Primer.</b></li> <li>4. <b>Supply of Adhesive membrane.</b></li> <li>5. <b>Expatriate Supervision</b></li> <li>6. <b>Supply of Electric mixing machine.</b></li> </ol> <p><b>Please clarify.</b></p> |              |

**BB) Extension of Last Date for Offer Submission:**

The last date for submission of Offer has been re-scheduled to 19/05/2021, 13.00 hrs.

Technical Bids (Part-1) shall be opened on 19/05/2021 at 17.00 hrs.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → [www.eprocurebhel.co.in](http://www.eprocurebhel.co.in)

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,  
Yours faithfully,

AGM (Purchase)