



BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-26-Sep-19

CORRIGENDUM- 09

|            |   |                               |
|------------|---|-------------------------------|
| PROJECT    | : | 1X660 MW BHUSAWAL TPS UNIT 06 |
| PACKAGE    | : | PRETREATMENT PLANT            |
| ENQUIRY NO | : | E-6274/2019 Dated. 30.07.2019 |
| SUBJECT    | : | TECHNICAL AMENDMENT           |

| Type of Corrigendum     |                                     |                          |                          |
|-------------------------|-------------------------------------|--------------------------|--------------------------|
| Technical Corrigendum - | <input checked="" type="checkbox"/> | Commercial Corrigendum - | <input type="checkbox"/> |

In reference to the above mentioned tender enquiry for **PRETREATMENT PLANT** package

Please note the following.


Technical amendment attached with this corrigendum shall be considered as part of NIT.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

R P Yadav  
Dy. Manager



## ANNEXURE-A

The following modifications/addition defined in SCHEDULE A below, with respect to Technical Specification for PRE TREATMENT PLANT (PT PLANT) BHEL's Technical specification no PE-TS-415-158A-A001 shall apply.

SCHEDULE-A

## NEW CLAUSE ADDED

| Sl no. | Vol. No. | Section/ Description          | Clause no | Page no    | Existing clause/details | Addition to existing requirement                                                                                                                                                                                                                                                                                                                                                                      |
|--------|----------|-------------------------------|-----------|------------|-------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1      | IIB      | SECTION- C1/ P&ID of PT Plant | Note 14   | 74 of 3099 |                         | Gravity filter/s indicated in P&ID is just a pictorial representation only. Number and type of gravity filter/s shall be as per requirement covered in <b>SCOPE OF SUPPLY AND DATA SHEET -A</b> . Accordingly, bidder shall provide associated piping, valves, fittings instruments and civil structure etc to fulfil the specification requirement as mentioned in Data Sheet A and scope of supply. |

*[Handwritten signature]*

Rebut Wünsche / sr med-max

James H. Brown