

ADDENDUM-1

DATE: 19-07-2021

AC & Ventilation Package for 2X800 MW Telangana Super Thermal Power Project-Karimnagar

Tender Ref: 77/21/6036/DSP

"Extension of due date for submission of offer"

Due date for submission of Offer has been extended to 30.07.2021

Submission of offer by 1.00 PM on 30.07.2021

Opening of Techno commercial bid at 4.00 PM on 30.07.2021

"Replies to Bidder queries"

Replies to bidder queries as attached shall form part of Tender document

Any further addendum such issued carry part of the bidding documents and this will be available at the web site from where the original documents have been received / downloaded by the bidder. Hence, bidders are requested to visit the web site on regular basis.

For Further Queries if any, Contact:

For Commercial :

Sh. D S Pradeep Kumar Sarma

Manager / MM

BHEL-ISG,

Prof.C.N.R.Rao Circle,

Bangalore-560 012

Off: 080 2218 4520,

e-mail: dsp@bhel.in

For Technical :

Sh. Indrajit Dey

Sr Manager / PE / Mech

BHEL-ISG,

Prof.C.N.R.Rao Circle,

Bangalore-560 012

Off: 080 2218 4219,

e-mail : idey@bhel.in

Bidder Queries	BHEL Reply
<p>As per title of the BHEL DBR (Doc. No.: IS-4-DC-701-110-M037, Rev.-05) it is mentioned that UAF unit for Ventilation System. But for fans static pressure calculation, no pressure loss is considered for UAF unit. Also, as per NTPC Drawing No.: 9591-102-155-PVM-L-004, Rev.-1, sheet no.-7, UAF unit is shown in MCC room Ventilation system.</p> <p>Please clarify whether the UAF unit is considered for the Ventilation system or not</p>	<p>UAF mentioned in Title description & Air Washer Unit mentioned in MCC room ventilation layout are typographical errors which shall be corrected in next revision submission to customer for CAT-I approval.</p> <p>Bidder may pl. ref. Ventilation Fan Equipment Drg (Drg No: 9591-102-155-PVM-L-004 Rev-5, Page 11 of 23) and quote accordingly</p>
<p>We have received the DBR as per BHEL Doc. No.: IS-4-DC-701-110-M037, Rev.-05, but there is no approval stamp on it. Please provide the same</p>	<p>We have uploaded Stamped Drg only, bidder may pl. check cover sheet of IS-4-DC-701-110-M037, Rev.-05 for NTPC digital Signature & Cat-II approval</p>
<p>We have considered our scope of work as per followings, Please Confirm-</p> <p>a) Supply of required Centrifugal, Axial, Bifurcated and Propeller fans with Motor.</p> <p>b) Supply of total GI Duct with accessories.</p> <p>c) Supply of A.C system only for DCS RIO Room.</p> <p>d) Scope of electrical work shall be as per Sl. No.-D, Page No.-11 of 15 of technical enquiry specification(Doc. No.: IS-4-15-2003/VAC(R)).</p>	<p>Bidder may pl. check & consider the scope of Work in line with our Specification / NIT documents as enclosed with Enq. No. 77/21/6036/DSP.</p>