



Enquiry Ref. No.:- PE/PG/NTF/E-6745/2021 dated 20.08.2021

Project 2X500MW NTPL TUTICORIN FGD

Package: OIL FILLED SERVICE TRANSFORMER

Ref. :- PE/PG/NTF/E-6745/2021

Date 31.08.2021

DUE DATE
07.09.2020
BY 02:00 P.M.

**CORRIGENDUM-1**

Following points shall be part of NIT

1. Impedance for transformers mentioned at S. No. 11 of Datasheet-A of Technical Specification shall be subject to IS tolerance.
2. The Load losses for transformers at S. No. 1 of Annexure-B (TRANSFORMER LOSSES) of Section-B of Technical Specification shall be as given below:

Ratings	Maximum No-Load losses at rated frequency and 100% Voltage	Maximum Load Losses at normal ratio, rated current and 75 deg.C
<u>2.5MVA</u>	2.8 KW	<b>30 KW</b>

3. Vendor to start manufacturing activities only after obtaining specific manufacturing clearance from BHEL Purchase group.
4. In case BHEL manufacturing clearance date is later than the date of Cat-1 approval of Primary drawing/documents, then the contractual delivery period will be calculated by setting off the time gap between Cat-1 approval date of Primary drawing/documents and the manufacturing clearance date, from any delay by vendor in submission/re-submission of Primary drawing/documents.

Above point 3&4 are to be considered the part of delivery schedule mentioned in annexure-A of NIT.

5. Due date of the tender is extended to 2:00 P.M. of 07.09.2021, bid shall be opened on 07.09.2021 at 5:00 PM.

All other terms and conditions shall remain as per NIT and subsequent corrigendum, if any.

With Regards,

(Saumya Pandey)  
Dy Manager/PG-I  
BHEL-PEM

Saumya Pandey  
DY MANAGER/PG-I,  
BHEL/PS-PEM  
POWER PROJECT ENGINEERING INSTITUTE,  
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)  
(OFF) 0120-4213543

Regd. Office:  
BHEL House  
Siri Fort  
New Delhi-110049