

Corrigendum - 1 dated 20/08/2024 to CPC Tender No. BHEL/CPC/SGL/MM/25/028

Corrigendum - 1 dated 20/08/2024 To CPC Tender No. BHEL/CPC/SGL/MM/25/028 for the work of “Receipt, Unloading, Verifying, Shifting, Stacking, Preservation, Handling and Handing over of components of Boiler with auxiliaries including Mills & Feeders etc. ESP with auxiliaries, Steam Turbine & auxiliaries; Turbo-Generator & auxiliaries, Pumps with aux., Rotating machines, Tanks & Vessels, Complete Electrical, Controls And Instrumentation Equipments, Panels, Cables / Cable Trays and other related items including items of Boiler, TG & BOP’s packages; HP & LP Piping, Refractory & Insulation with Cladding materials, BHEL T&P; components & equipment of various other systems, Pre-fabricated Structures, Structural & Reinforcement Steel, Cement, Supply, Installation and Maintenance of CCTV Camera in Storage Area and providing services for Materials Management at 2 x 800 MW Singrauli STPP STAGE -III, District-Sonebhadra, Uttar Pradesh, India.”

Some of the Bidders sought clarifications in regard to the published tender specification. The clarifications issued by BHEL are as below;

Sl. No.	Reference clause of tender document	Existing Provision	Bidder’s Query	BHEL’s Clarification
1	Clause 1.9 EMD of GCC:	Earnest Money Deposit:	1. Requested for waiver of EMD for this tender.	Tender Conditions Prevail.
			2. We request for exemption of EMD because it is service contract only We have been registered in MSME and NSIC	
2	Clause No 2.1.11 of TCC	General cleaning, grass cutting and upkeep of storage yard, covered and semi-closed stores sheds within the quoted rates for unloading, verification and stacking.	<p>Please confirm the scope of grass cutting work and cost on account of the same to be limited to the extent of value identified in the contract under completion of contractual obligation</p> <p>From our recent experience at site, we found that since undeveloped, open space has to be used due to urgency of the project, mostly the open yard is being handed over as is where basis which is full of grass, weeds and vegetation and thereafter throughout the period of contract we were being forced to do the work of grass cutting and removal of the same which involves lakhs of rupees and</p>	<p>Refer clause 2.1.11 of TCC</p> <p>Developed open yard shall be provided to Bidder.</p> <p>Tender Condition prevails.</p>

Corrigendum - 1 dated 20/08/2024 to CPC Tender No. BHEL/CPC/SGL/MM/25/028

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification
			<p>multi fold to the value arrived as per the contract price.</p> <p>Hence, we would like to know the detailed scope of work under grass cutting to be carried out in different open yards for legitimate cost estimation.</p>	
3	Clause No 2.3 of TCC	BHEL reserves the right to recover from the contractor any loss arising out of damage/ theft or any other causes or during verification/stacking or at any time under the custody of the contractor.	<p>Since the security of the project will be under control with the customer NTPC and/or BHEL, then in case of theft why the recovery to be made from the contractor?</p> <p>Please define the term "custody of the contractor". As per our understanding after unloading of materials the custody of the materials will be with BHEL.</p> <p>Please clarify.</p>	<p>Given the nature of work which includes receipt, unloading, verifying, shifting, stacking, preservation, handling and handing over of different components of power plant of huge cost, the material handling agency is required to maintain utmost integrity.</p> <p>At Singrauli project, BHEL will engaging security agency for storage premises.</p> <p>However, the bidder is not absolved from watch and ward in case of pilferage/theft.</p>
4	Clause No 4.1.2 (Table) Serial no. 4 of TCC	<p>Deployment of other T&P</p> <p>TRAILER WITH PRIME MOVER-40T or above from 4th month for 41 months</p>	<p>No hire charge is payable against deployment of 40T Trailer. Whether deployment for the scheduled period is mandatory or this can be deployed as per requirement. If no hire charges is payable against 40T Trailer, the cost will unnecessarily on higher side.</p> <p>Please clarify.</p>	Included in scope of work within quoted rates.

Corrigendum - 1 dated 20/08/2024 to CPC Tender No. BHEL/CPC/SGL/MM/25/028

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification
5	Clause No 4.1.2 (Table) Serial no. 11 of TCC	Tarpaulin (Fire Proof) Assorted Size 200 nos.	Please specify the approx. area in square meter / square feet to be provided. Without having the total area requirement cost estimation is not possible. Or else please specify the size of the tarpaulins to be provided.	Assorted size with area not less than 500 SqFt each may be provided.
6	Clause No 4.2.5 of TCC	<p>Mostly all consignments planned for this project will be within the capacity of cranes mentioned in above table in contractor's scope. However, if required the contractor shall arrange additional 1 No. of 40 MT crane to ensure proper unloading of material as per direction of BHEL Engineer.</p> <p>Also, Bidder shall mobilise adequate no. of Farana in addition to cranes mentioned in Clause 4.1.2 above, to ensure proper unloading of material as per direction of BHEL Engineer.</p> <p>In addition to abovementioned requirement, BHEL shall provide the crane of capacity 40MT or above (without Diesel) to Contractor at no cost to bidder. The arrangement of fuel in such case shall be the responsibility of contractor with no extra cost.</p>	<p>In case of deployment of additional 40T Crane & Farana if required, hire charges against the same will be paid additionally as per item B of the Schedule of Rates.</p> <p>Please confirm</p>	Hire charges of the respective crane as classified in Section -B of SCHEDULE OF RATES AND QUANTITIES shall be paid.
7	Clause No 9.17.2 of TCC	<p>Preservation of Components:</p> <p>BHEL WILL PROVIDE FREE OF COST ALL PRESERVATIVES LIKE PRESERVATIVE OIL, LUBRICANTS, CHEMICALS, INHIBITORS, CAPS ETC EXCEPT PRIMERS & PAINTS. CONTRACTOR SHALL PROVIDE RED OXIDE ZINC CHROMATE (ROZC) PRIMER CONFORMING TO IS: 2074 OF REPUTED MANUFACTURES (E.G. ASIAN PAINTS, BERGER, JENSON & NICHOLSON, BOMBAY</p>	Please provide the quantity requirement of ROZC for the purpose of estimation.	As per requirement during execution.

Corrigendum - 1 dated 20/08/2024 to CPC Tender No. BHEL/CPC/SGL/MM/25/028

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification
		<p>PAINTS, SHALIMAR OR ANY OTHER BHEL APPROVED MANUFACTURER) REQUIRED FOR PRESERVATION SHALL BE PROVIDED BY THE CONTRACTOR AND USED FOR THIS PURPOSE.</p> <p>In the process.....prescribed formats.</p>		
8	Clause No 9.20 SI No 4, 5 & 6 of TCC	<p>4. Regular repair, maintenance and upkeep of all installations & facilities of weigh bridge arising out of wear and tear during use particularly of ramps and platforms shall be maintained for satisfactory availability and operation of weigh bridge. All cost towards these incidental charges are in contractor's scope.</p> <p>5. Contractor at all times during the currency of this contract shall possess necessary license, permits as applicable to the provision of the operation of weigh bridge and pay all fee and charges as may be applicable. BHEL shall in no way be held responsible for any of the lapse of the contractor.</p> <p>6. Contractor has to ensure the availability of operational weigh bridge to the maximum as possible. All the breakdowns or operational/preventive maintenance are to be arrange by the contractor in consultation with the BHEL. All the cost (inclusive of spares and other supplies) towards the breakdowns or operational/preventive maintenance is in the scope of the contractor. If contractor fails to maintain the weigh bridge operationality then BHEL reserves the right to take appropriate action for making the</p>	<p>The weighbridge will not be used by the MM vendor for its own T&P and vehicles.</p> <p>Then what is the purpose of maintenance of ramp/approach road by MM vendor? This should be under the civil contract. Installation of weighbridge would be a contract between BHEL and the installation agency. The MM vendor will not have any information and/or quality checks of the weighbridge.</p> <p>Since the weighbridge would be owned by BHEL and installed by any other third party, then how the maintenance of the weighbridge along with cost of spares is in the scope of the MM vendor under this contract.</p> <p>Please clarify</p>	<p>Tender condition prevails.</p> <p>Bidders requested to go through tender conditions carefully before submitting their offer.</p>

Corrigendum - 1 dated 20/08/2024 to CPC Tender No. BHEL/CPC/SGL/MM/25/028

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification
		weigh bridge operational on cost recovery basis from Contractor plus 5% overheads. Any charges paid by BHEL towards operation & maintenance of weigh bridge shall be deducted from contractor's due bills		
9	Clause No. 13 of TCC	Supply installation and maintenance of CCTV cameras	<p>During site visit on 16-08-2024, as discussed with BHEL officials, we understand that CCTV installation to be done along the periphery of the storage yard. Whether laying of power cable will be within the scope of MM vendor? If yes, please share the total requirement in meter for estimation purpose.</p> <p>We understand that cost of power usage towards operation of CCTV to be borne by BHEL</p> <p>Please clarify/confirm.</p>	<p>For CCTV cameras at different locations power sources shall be provided at nearby locations.</p> <p>Power usage charges towards operation of CCTV system shall not be borne by Contractor.</p>

Note:

- 1) All other terms and conditions against this NIT shall remain unchanged.
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).

**for BHARAT HEAVY ELECTRICALS LTD
AGM / SCT- CPC**