

Corrigendum - 1 dated 07/03/2025 to CPC Tender No. BHEL/CPC/RTP/BLR_FGD/25/086

Name of work - "CIVIL, STRUCTURAL & ARCHITECTURAL WORKS INCLUDING SITE FABRICATION & STRUCTURAL ERECTION WORK OF SHOP FABRICATED & SITE FABRICATED STRUCTURE FOR - BOILER, ESP, MILL & BUNKER BUILDING, FAN AND MILL FOUNDATIONS, ESP CUM FGD CONTROL ROOM, MAIN PLANT DUCT FOUNDATION, DAY SILO, GYPSUM DEWATERING BUILDING, FGD ABSORBER, CHIMNEY RAFT, COMPRESSOR HOUSE, PIPE/ CABLE RACK, MISC. MCC BUILDING & CONTROL ROOM, OCCUPATIONAL HEALTH CENTRE, LABOUR HUTMENT FOR WORKERS INCLUDING LAND LEASING ETC., ACW PUMP HOUSE, DG FOUNDATION, FGD TANKS, SUMPS , PUMPS, DUCT FOR FGD, BALL MILL BUILDING, FOPH, ROOF TOP SOLAR CIVIL WORKS, AC & VENTILLATION DUCTING , SHEDS FOR CONSTRUCTION WORKERS AND O&M WORKERS, ROADS & DRAINS ETC. AT 2X660MW DVC RAGHUNATHPUR (RTPS) PHASE-II, RAGHUNATHPUR, WEST BENGAL".

A) Some of the Bidders sought clarifications in regard to the published tender specification. The clarifications issued by BHEL are as below;

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification
1	Technical Conditions of Contract (TCC) Chapter – II: SCOPE OF WORKS, Clause 2.1	CIVIL, STRUCTURAL & ARCHITECTURAL WORKS INCLUDING SITE FABRICATION & STRUCTURAL ERECTION WORK OF SHOP FABRICATED & SITE FABRICATED STRUCTURE FOR- BOILER, ESP, MILL & BUNKER BUILDING, FAN AND MILL FOUNDATIONS, ESP CUM FGD CONTROL ROOM, MAIN PLANT DUCT FOUNDATION, DAY SILO ,GYPSUM DEWATERING BUILDING, FGD ABSORBER, CHIMNEY RAFT, ROADS & DRAINS ETC. FOR UNIT#3 & UNIT#4.....	The nomenclature of the work indicates "SITE FABRICATION & STRUCTURAL ERECTION WORK OF SHOP FABRICATED & SITE FABRICATED STRUCTURE FOR - BOILER, ESP" However as per TCC the scope of structural site fabrication and erection of shop fabricated structure does not indicate Boiler and ESP structure. Kindly clarify.	Bidders are requested to refer to Clause-2.2 of Chapter -II of TCC, for scope clarity. Further refer Clause - 2.2.2 of TCC for the structures for which site fabrication & erection is to be done and Clause -2.2.3 of TCC for the Shop fabricated structures for which erection is to be done.
2.	BOQ CUM RATE SCHEDULE (BOQ) – Item D2301	Fabrication(Site Welded as per specification,), transportation from fabrication yard and erection of Mild structural steel.....	The weightage allotted to structural fabrication and erection including supply of bolts seems to be on lower side-kindly advise	Weightage distribution is ok. Tender conditions shall prevail.

Corrigendum - 1 dated 07/03/2025 to CPC Tender No. BHEL/CPC/RTP/BLR_FGD/25/086

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification
3.	BOQ CUM RATE SCHEDULE (BOQ) – BOQ item A207	Providing and laying Design Mix cement concrete confirming to IS:456 & IS 10262-2009 for reinforced concrete works.....	BOQ item no A207 indicates TG foundation and Top deck but the scope of the work does not indicate the same- Kindly clarify	TG foundation and Top deck are not in scope. Item no. A207 is applicable for other machine foundations which are in scope, in line with Clause- 2.2 of TCC.
4.	BOQ CUM RATE SCHEDULE (BOQ) – BOQ item B111	Supplying and filling clean and well graded Crushed stone sand (conforming the deleterious materials.....	The weightage allotted to BOQ item no B111 for crushed stone aggregate seems to be on lower side (as per available syndicate rates)- Kindly clarify.	Weightage distribution is ok. Tender conditions shall prevail.

Note:

- 1) All other terms and conditions against this NIT shall remain unchanged.**
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).**

for BHARAT HEAVY ELECTRICALS LTD
Manager/ SCT- CPC