

Ref: BHE/PW/PUR/2106057/Corg-10, Date: 30/07/2021

-----Page 1 of 2-----

To
ALL BIDDERS,
Sub: Corrigendum-10: Clarifications to Pre-Bid Queries by bidders & Amendment to the tender conditions

Reference:

- E-Tender Specification. No: 2106057**
- Scope of work:** Design, manufacture, assembly, inspection & testing at vendor's/ sub-vendor's works, proper packing and delivery to site, Erection & Commissioning of LIGHTING FIXTURES, LAMPS & MISCELLANEOUS ITEMS as mentioned in different sections of this specification, complete with all accessories for efficient and trouble-free operation for Owner's Office and Owner's Storage at 3x800MW PVUNL Patratu Project.

Corrigendum Ref: -

Sl. No.	Corrigendum Ref	Corrigendum Type
1	Corrigendum-01	Time extension
2	Corrigendum-02	Amendment to Tender document
3	Corrigendum-03	Time extension
4	Corrigendum-04	Clarification to bidder's query & Amendment to Tender document
5	Corrigendum-05	Time extension
6	Corrigendum-06	Clarification to bidder's query & Amendment to Tender document
7	Corrigendum-07	Time extension
8	Corrigendum-08	Clarifications to Pre-Bid Queries by bidders & Amendment to the tender conditions
9	Corrigendum-09	Time extension

Ref: BHE/PW/PUR/2106057/Corg-10, Date: 30/07/2021

-----Page 2 of 2-----

Bidders to kindly take note of the following:

AA) Clarifications to Pre-Bid Queries by bidders & Amendment to the tender conditions

S. No.	Cl. Of Tender Specification	Description	Bidder's Query	BHEL Clarifications/ Amendment to the tender conditions
1	BOQ Sl. No. 4.4	LAN HUB	Please provide the model number of network switches required for LAN Hub. Also please clarify that Master switching systems (which control 3 hubs) are also in our scope or not.	Model No. cannot be specified however as per shared specifications; Layer-2 non-POE Network Switch may be required for only LAN data communication.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL→
<https://eprocurebhel.co.in>

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

GM (Purchase)