

## Corrigendum - 11 dated 24/01/2026 to CPC Tender No. BHEL/CPC/KOD/EPC AHP PKG - II/26/058

**Corrigendum - 11 dated 24/01/2026 to CPC Tender No. BHEL/CPC/KOD/EPC\_AHP\_PKG - II/26/058** for the work of “EPC Package (Package – II) for Main Ash Handling System of Unit#3 & Unit#4 at 2x800 MW DVC Koderma TPS Phase-II, Jharkhand”.

**A) Time Extension:** Clause No. 1.0 Salient Features of NIT in NOTICE INVITING TENDER is revised as below:

Sl. No.	Clause No.	Existing in Tender	Revised vide Corrigendum - 1	Revised vide Corrigendum - 2	Revised vide Corrigendum - 3	Revised vide Corrigendum - 5	Revised vide Corrigendum - 6	Revised vide Corrigendum - 7	Revised vide Corrigendum - 8	Revised vide Corrigendum - 9	Revised As
1	Sl. No. v) DUE DATE & TIME OF OFFER SUBMISSION.	Date: 01/12/2025, Time: 10:00 Hrs	Date: 11/12/2025, Time: 10:00 Hrs	Date: 16/12/2025, Time: 10:00 Hrs	Date: 22/12/2025, Time: 10:00 Hrs	Date: 30/12/2025, Time: 10:00 Hrs	Date: 06/01/2026, Time: 10:00 Hrs	Date: 14/01/2026, Time: 10:00 Hrs	Date: 21/01/2026, Time: 10:00 Hrs	Date: 24/01/2026, Time: 12:30 Hrs	<b>Date: 28/01/2026, Time: 12:30 Hrs</b>
2	Sl. No. vi) OPENING OF TENDER	Date: 01/12/2025, Time: 16:30 Hrs	Date: 11/12/2025, Time: 16:30 Hrs	Date: 16/12/2025, Time: 16:30 Hrs	Date: 22/12/2025, Time: 16:30 Hrs	Date: 30/12/2025, Time: 16:30 Hrs	Date: 06/01/2026, Time: 16:30 Hrs	Date: 14/01/2026, Time: 16:30 Hrs	Date: 21/01/2026, Time: 16:30 Hrs	Date: 2/01/2026, Time: 17:00 Hrs	<b>Date: 28/01/2026, Time: 17:00 Hrs</b>

**B) Some of the Bidders had asked queries in the published tender specification. The clarifications issued by BHEL are as below;**

Sl. No.	Section/ Clause No	Existing Provision	Bidder's Query	BHEL Clarification
1	Amendment No. 8 to Bid specification, S.No. 1, capacity specified for bulker unloading below BAIM Silo	40-120 TPH during open truck/Bulker loading through Conditioned ash unloader (BAIM)	Kindly note that in the drawing No. 3112-108-POM-A-910 marking the division of scope for DBA Vendor (Package-I) scope and Main Ash Handling Vendor (Package-II) scope, unloading below the BAIM silo is clearly marked as DBA vendor scope. Hence the unloader of 40-120 TPH is not in our scope under this package. Please confirm as this has major price implication.	The boundary limits of the Main Ash Handling Package are already defined in the scope matrix provided with this tender. Accordingly, bidder is requested to adhere to the points applicable to the Main Ash Handling System.
2	Amendment No. 8 to Bid specification, S.No. 2, capacity specified for bulker unloading below BAIM Silo	1.Vibrator below BAIM silo for conveyors – 260-286 TPH 2. Vibrator below BAIM silo for open truck – 40-120 TPH (VFD)	Kindly note that in the drawing No. 3112-108-POM-A-910 marking the division of scope for DBA Vendor (Package-I) scope and Main Ash Handling Vendor (Package-II) scope, unloading below the BAIM silo is clearly marked as DBA vendor scope. Hence the vibrators of 260-286 TPH and of 40-120 TPH is not in our scope under this package. Please confirm as this has major price implication.	The boundary limits of the Main Ash Handling Package are already defined in the scope matrix provided with this tender. Accordingly, bidder is requested to adhere to the points applicable to the Main Ash Handling System.

- 1) All other terms and conditions against this NIT shall remain unchanged.
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).

**for BHARAT HEAVY ELECTRICALS LTD  
Sr. Manager/ SCT**