

Corrigendum - 1 dated 27/06/2024 to CPC Tender No. BHEL/CPC/LRA/RMC/25/021

Corrigendum - 1 dated 27/06/2024 To CPC Tender No. BHEL/CPC/LRA/RMC/25/021 for the work of "Hiring of RMC Agency for Installation of Batching Plant & Production of Required Grade of Concrete for 2x800 MW Lara STPS Stage II, Raigarh, Chhattisgarh State, India".

A) Some of the Bidders sought clarifications in regard to the published tender specification. The clarifications issued by BHEL are as below;

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification
1	TCC, Chapter — III; Clause 3.2 Electricity:	Electricity for construction purposes - 3 Phase 415/440 V a) Single Point Source - Chargeable. Bidder to make own arrangement of distribution of electricity at its own cost.	Kindly provide as free of cost	Tender Conditions Prevail.
2	TCC, Chapter -II; Clause 2.19 Construction Water:	Construction water shall be arranged by bidder. Bidder has to make arrangement of further distribution of water at his own cost. No extra payment shall be made under this account.....	Construction water shall be arranged by BHEL as free of cost	Tender Conditions Prevail.
3	TCC, Chapter - VI: Clause 6.2 Schedule of Completion:	Schedule of Completion: The entire work under the scope of work shall be successfully completed in all respect as below: Supply of Ready-Mix Concrete (RMC): within 30 (Thirty) months from date of start of work	Hope, it is for completion of two projects only as we understand (for 800 MW more than 300000 cum required). As the Qty is on the lower side, whether the completion period of 30 months is enough?	Tender Conditions Prevail.
4	TCC Chapter - IV: Clause 4.2.1:	30 Cum/Hr. capacity of Automatic Batching Plant with Printing facility with minimum total 300T storage capacity silos for storing of Cement for each batching plant. – 2 Sets of Batching Plant. Batching plant installed shall have provision of feeding silos with cement bags also as per site requirement. – 1 st Within 45 days 2 nd within 75 days (Mobilization, Installation & Commissioning)	Aprox. 1,30,000 cum for 30 months - ie approx. 145 cum per day. As M30 Capacity plant can produce approx. 300 cum for continuous 10 hr., 1 set of batching plant will be sufficient, as we feel.	Tender Conditions prevail. 2 sets of Batching Plant to be installed.

Corrigendum - 1 dated 27/06/2024 to CPC Tender No. BHEL/CPC/LRA/RMC/25/021

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification
5	NIT Clause 1.0, sub clause vii, EMD AMOUNT	EMD AMOUNT - Rs. 20,00,000/- (Rupees Twenty lakh Only)	EMD may be waived off.	Tender Conditions Prevail.
6			Minimum guaranteed quantity per month.	An average concrete of 3000 - 4000 cum per month is envisaged in line with TCC Chapter -II, Clause No 2.5.
7			Work pertains to only production. Supply is not in the scope of work.	Refer TCC Chapter - II, Clause No 2.1. (d). Bidder to produce RMC at batching plant. Further transportation of RMC from Batching plant onwards is not in the scope of work for this tender.

Note:

- 1) All other terms and conditions against this NIT shall remain unchanged.
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).

for BHARAT HEAVY ELECTRICALS LTD
Manager/ SCT- CPC