

Corrigendum 2 dated March 08, 2021 to Tender Specification BHEL PSSR SCT 1935

Corrigendum 2 dated March 08, 2021 to Tender Specification BHEL PSSR SCT 1935 for the works of

Package A: Handling of Materials at BHEL / Client's Stores / Storage Yard, Transportation to site of erection, Erection, Testing, Commissioning & Trial Operation including supply and application of painting of Steam Turbine, Turbo Generator & auxiliaries, Bought Out Items for Unit-1 along with Sea Water Intake/Outfall Pumps and related Auxiliaries, and **Package B:** Handling of Materials at BHEL / Client's Stores / Storage Yard, Transportation to site of erection, Erection, Testing, Commissioning & Trial Operation including supply and application of painting of Steam Turbine, Turbo Generator & auxiliaries, Bought Out Items for Unit-2 at 2X660MW Udangudi Supercritical Thermal Power Project at Tuticorin District, Tamil Nadu".

A. Some of the Bidders had asked queries in the published Tender Specification. The clarifications issued by BHEL are furnished below: -

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's query	BHEL's Clarification
1	TCC, Volume IA Part –I, Chapter – VI Time Schedule 1.6.1.1	The entire work of erection testing and commissioning of the steam turbine completed within sixteen (16) months from the date of commencement of work of respective package at site.	Provide phase shift for Package A & B	Phase shift between Unit 1 & Unit 2 is 2 months. Unit 1 will be taken up first.
2	TCC, Volume IA Part-I, Chapter –IX, 1.9 Bill of Quantity	Package A D BOI Items & Package B D BOI Items	Kindly share the details of weight in each items	Detailed Engineering is in progress for the BOI Items. However, tentative total weight is already indicated in the tender. Bidder to quote accordingly.
3	TCC, Volume IA Part-I, Chapter –XVI, Hydraulic test 1.16.1	The hydraulic testing of the equipment and piping, covered under this scope of work has to be carried out by the contractor as per instructions of BHEL Engineer. The contractor shall provide all facilities required for hydraulic testing	Kindly confirm, whether water for hydro test provided by BHEL. Free of cost.	Hydro test water shall be arranged by the bidder within the quoted rates.

ALL OTHER CONDITIONS REMAIN UNCHANGED.

BIDDERS ARE REQUESTED TO CONSIDER THIS CORRIGENDUM AS PART OF TENDER SPECIFICATION AND QUOTE ACCORDINGLY.

-Sd-
(M.Selvan)
Sr.Engineer./Subcontracts