

Corrigendum-2 (Technical)

This corrigendum is issued against Clause no. 7 of Annexure I of enquiry E7033021 to delete requirement of Kraft Insulating paper – Low air permeability with specification no. AA21116 Rev 03, Grade 5B4-2L4 of IEC554-3-5 as mentioned in point no. ii of the clause under Insulating Paper. Accordingly requirement of insulating paper mentioned in clause no. 7 of Annexure I is amended as mentioned below:

Insulating paper for use as Conductor covering		
Sl. No.	Type of Paper	Specification no.
i	Kraft Insulating Paper - High air permeability (for use as covering)	AA21111 Rev 06. The Kraft paper shall completely comply to all parameters as per grade 5B2-2H1 of IEC 554-3-5 for all thickness size of paper.
ii	Normal Density Thermally Upgraded paper (for use as covering	TRE 218 Rev 01
iii	High Density Thermally upgraded (For use as covering)	Weidmann make 22HCC or Cindus Make 42HCF

All the other terms and conditions shall remain same.