



BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-6-Aug-21

CORRIGENDUM-3

PROJECT	:	1 x 660 MW BHUSAWAL PROJECT
PACKAGE	:	CONTROL VALVE
ENQUIRY NO.	:	PE/PG/BHU/E-6682/2021 Dtd. 06.07.2021
SUBJECT	:	DUE DATE EXTENSION, Reply of Pre-Bid Query

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input checked="" type="checkbox"/>

In reference to the above mentioned tender enquiry for **CONTROL VALVE** package, please note the following.

1. Due date has extended from **06.08.2021, 02:00 P.M.** to **13.08.2021, 02:00 PM**. Bid opening shall be done at 05.00 PM on due date.

2-Further, please note the BHEL reply on Pre-Bid Technical queries: -  
Multistage-Multi-path design along with leakage class equal or better than class V with metal to metal seating shall be considered for FDV-14 control valve tag.

However, for other valves anti cavitation trim shall be provided for all the tags in which cavitation is present or foreseen along with the leakage class as per technical specification/datasheets.

All the other terms and conditions of the tender enquiry remain unchanged.

Yours faithfully,

For and on behalf of BHEL