



ಭಾರತ್ ಹೆವಿ ಎಲೆಕ್ಟ್ರಿಕಲ್ಸ್ ಲಿಮಿಟೆಡ್

(ಭಾರತ ಸರ್ಕಾರದ ಉದ್ಯಮ)

भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Government of India Undertaking)

INDUSTRIAL SYSTEMS GROUP

ಫೋನ್/ Phone : (080)-22184520

ಫೇಕ್ಸ್/ Fax : (080)- 2356 2713

ई-मेल/e-mail: dsp@bhel.in

ಮೊಬೈಲ್/Mobile: 9008242882

ಪೊ.ಬಾ.ನಂ. 1249, ಪ್ರೊ.ಸಿ.ಎನ್.ಆರ್.ರಾವ್ ಸರ್ಕಲ್,

आईआईएससी पोस्ट, मल्लेश्वरम, बेंगलूरु-560012,

P.B.No.1249, Prof. CNR Rao Circle, IISc Post,

Malleswaram, Bengaluru-560 012. India

Our Ref: 77/24/6122/VVN

Dt: 07-01-2025

Subject: Regarding publishing of Corrigendum of Replies to bidder queries for Enq.No: 77/24/6122/VVN.

With reference to the above enquiry for supplying Stacker cum Reclaimer Package for NLCIL , Talabira Thermal Power Station (3x800 MW), we are publishing Corrigendum of Replies to bidder queries as enclosed .

Thanking You,

Yours faithfully,

For BHARAT HEAVY ELECTRICALS LTD

(D S Pradeep Kumar Sarma,Sr Manager, PG-II)

पंजीकृत कार्यालय बीएचईल हाउस, सिरि फोर्ट, नई दिल्ली - 110049

वेबसाइट : www.bhel.com, कॉर्पोरेट पहचान संख्या : L74899DL1964GO1004281

Regd. Office: 'BHEL House', Siri Fort, New Delhi - 110049

Website : www.bhel.com, Corporate Identity Number : L74899DL1964GO1004281

Stacker cum Reclaimer Package for Talabira Thermal Power station (3x800 MW)
BHEL Tender ref. No. 77/24/6122/VVN

Sl. No.	Tender Document Description	Clause No.	Page No.	Existing Provision	Bidder's Query	Clarification by BHEL
1	VOLUME II A Part II	4.01.00	5 of 114 Or PDF Page no. 2066 out of 3473	Belt Conveyor & Accessories - All discharge pulleys of conveyors shall be provided with split bearings:	<p>We have observed that all discharge pulleys of conveyors are to be provided with split bearings.</p> <p>Please let us know whether this clause is applicable to the stacker-cum-reclaimer pulleys i.e. for boom conveyor, Intermediate conveyor, cross belt conveyor & tripper discharge pulleys.</p> <p>If split bearings are applicable, then please confirm the approved split bearing vendors.</p>	<p>Type of Bearings for Pulleys "Type of bearings for all pulleys shall be heavy duty, self-aligning, anti friction double row type spherical roller bearings (non split type) shall be provided".</p> <p>Above clarification is provided by NLC in SI no 25 in Annexure C2C of the corrigendum-5 (Page no 1208 of 1335) in the amendments and clarifications of tender documents. Bidder to kindly refer the same.</p>
2	Annexure -7 Electrical & C&I Spares List	Note 9	Page No. 5 of 5	Bidder to refer Annexure - I 6 for other applicable C&I spares in addition of the items list in this section	<p>Unable to locate the mentioned document.</p> <p>Kind request to share the document or the path to locate it.</p>	<p>Please refer NLC NIT Specification, Volume IIA, Section-IX, Mandatory Spares-C&I</p> <p>LIST OF MANDATORY SPARES FOR CONTROL & INSTRUMENTATION</p>