

Corrigendum - 4 dated 22/07/2026 to CPC Tender No. BHEL/CPC/UKI/M BLR MM/27/028

Corrigendum - 4 dated 22/07/2026 to CPC Tender No. BHEL/CPC/UKI/M_BLR_MM/27/028 for the work of

“Package - A: Erection, Testing, commissioning, Trial Operation and handing over of Boiler and its auxiliaries including Pressure Part, Non-Pressure Parts, Duct dampers and its support structure, Auxiliary Boiler, Rotating Equipment’s, Air Pre-Heaters, ID/FD/PA fans, Mills, Refractory etc. along with application of lining, Insulation, NDT, supply & final Painting/ Touch-up painting as applicable and wherever required as per painting schedule including Handling of materials at BHEL/ Client's Stores/ Storage Yard and transportation to site at 1x800 MW GSECL UKAI TPS (Unit#7), Tapi District, Gujarat.

Package – B: Material Handling and Management including Receipt, unloading, verifying, shifting, stacking, preservation, handling and handing over of components of Boiler with auxiliaries including Mills & Feeders etc.; ESP with auxiliaries, Steam Turbine & auxiliaries; Auxiliary Boiler, Turbo-Generator & auxiliaries; Pumps with aux., Rotating machines, Tanks & Vessels, Electrical, Controls and Instrumentation equipments, Panels, Cables / Cable trays, and other related items including items of Boiler, TG & other packages; HP & LP piping; Refractory & Insulation with cladding materials; BHEL T&P; components & equipment of various other systems, Pre-Fabricated Structures, Structural & Reinforcement steel, Cement, supply installation and maintenance of CCTV camera and providing services for Materials Management at 1x800 MW GSECL UKAI TPS (Unit#7), Tapi District, Gujarat”.

A) Some of the Bidders had asked queries in the published tender specification. The clarifications issued by BHEL are as below;

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
1	TCC; Chapter II: Scope of Work	Broad area of works divided into 02 different packages	- It is not clear that whether we should quote for Pkg A or Pkg B as both have different financial implication. - Also, kindly brief on modality of awards.	- Bidder has to quote for total scope i.e. for both Packages. Bidders to refer Chapter-XXV of TCC in this regard. - Bidder to refer Chapter-XXV of TCC for modality of award.

Corrigendum - 4 dated 22/07/2026 to CPC Tender No. BHEL/CPC/UKI/M BLR MM/27/028

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
2	TCC; Chapter II: 2.5.11	Lodging of complaint...shall be in the bidder's scope.	- We wish to clear that bidder shall not be liable for any kind of theft. At this is preventable but chances of theft are more due to varied reasons. - Insurance of Erectable items in bidder scope. - Bidder shall install stage, further maintenance, replacement of spares in BHEL Scope. As this cost cannot be estimated at bidding stage. This clause is not acceptable.	- Tender condition shall prevail. - Insurance of BHEL supplied items shall be in BHEL scope. Bidders are requested to refer clause no. 2.18 of GCC in this regard. - Bidder's query is not clear. Tender condition shall prevail.
3	TCC; Chapter II: 2.5.38	As far as possible Local labourer's shall be engaged for unskilled work by the contractor..... regard to the local religious festivals & customs.	Engagement of local labours is subject to site conditions. We suggest to work with migrant labour for better control discipline and progressive work and avoiding site disturbances.	Tender condition shall prevail.
4	TCC; Chapter II: 2.6.7	Medical/First aid center/medicine Contractor shall arrange for the above facilities till the time BHEL provided common facility is operational.	We request to consider to divide the equally among all agencies working inside the plant.	Tender condition shall prevail.
5	TCC; Chapter II: 2.9.9	Painting: Structure: All structures shall be..... supply of the required paints and primers and associated consumables shall be carried out as mention in the painting schedule of the respective units.	Please note that 'touch up paint' is considered as a limited due. Any paint 'peel off' due to material transit/prolonged stay at material yard shall not be treated as 'touch up'.	Bidder's understanding is not correct. Tender condition shall prevail.

Corrigendum - 4 dated 22/07/2026 to CPC Tender No. BHEL/CPC/UKI/M BLR MM/27/028

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
6	TCC; Chapter III: 3.14.1	Construction Water	We request BHEL to provide water for construction from start of project, 3 months of initial stage is considerable long period and will have corresponding cost in estimate.	Tender condition shall prevail. However, Bidders to note that Construction water is currently available at site.
7	TCC: Chapter IV: 4.1	For Package A Major T&P: 1. Crawler Crane -150MT-1no. 2. Crawler Crane – 75MT-1no.	Crawler Crane till synchronization is long period as the subject activity can extended beyond control of contractor and due to varied reasons. Hence this to treated as maximum Drainable hydrotest.	Tender condition shall prevail. Sl. no. 2 of Notes for Clause no. 4.1 mentioned in Chapter-IV of TCC may be referred in this regard for better understanding.
8	TCC: Chapter IV: 4.1	For Package A Major T&P: 3. Crawler Crane – 75 MT-1no.	Completion of mills/ducting works is subject to availability of materials/ sequent work fronts, with current scenario all per critical. Power projects are being delayed due to non-availability of work fronts/ materials. Hence this to be treated as 18 months from start of project.	Tender condition shall prevail. Sl. no.2 of Notes for Clause no. 4.1 mentioned in Chapter-IV of TCC may be referred in this regard for better understanding.
9	TCC: Chapter IV: 4.1	For Package A Major T&P: 4. Tyre mounted crane- 75/80 MT-1no.	To be treated as 18 months.	Tender condition shall prevail.
10	TCC: Chapter IV: 4.1	For Package A Major T&P: 5. Temporary lift 1.5MT capacity.	If project is delayed due to reasons beyond ours control, the lift should be allowed to be dismantled.	Tender condition shall prevail. Sl. no.2 of Notes for Clause no. 4.1 mentioned in Chapter-IV of TCC may be referred in this regard for better understanding.

Corrigendum - 4 dated 22/07/2026 to CPC Tender No. BHEL/CPC/UKI/M BLR MM/27/028

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
11	TCC: Chapter IV: 4.1	For Package B Major T&P	The end period shall be completion of major material handling that too within contractual timeline (ie., 21 st month, as per TCC, Chapter-VI time schedule 6.3.1)	Tender condition shall prevail. Sl. no.2 of Notes for Clause no. 4.1 mentioned in Chapter-IV of TCC may be referred in this regard for better understanding.
12	TCC: Chapter IV: 4.2	For Package B Major T&P: 9. Man lifter – min.40mtr height capacity	“Subject to availability at market”; please remove the ‘length of the item’.	Tender condition shall prevail.
13	TCC: Chapter IV: 4.2	For Package B Major T&P: 14. Pre-heating, Post-.....	Chartless recorder is subject to availability at market and corresponding cost will be higher in estimation. Hence please consider; printing type recorder which is being used widely at running projects.	Tender condition shall prevail.
14	TCC: Chapter IV: 4.2	For Package B Major T&P: 78. PVC caps to cover Pipe/tube ends	To be provided by BHEL.	Tender condition shall prevail.

- 1) All other terms and conditions against this NIT shall remain unchanged.
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).

for BHARAT HEAVY ELECTRICALS LTD
Dy. General Manager/ SCT