

Corrigendum - 1

Project : - 3X800 MW PVUNL PATRATU TPP PHASE-I

Package :- CABLE TERMINATION & JOINTING KITS

Bid Number: GEM/2021/B/1365520 Dated: 17-07-2021

This is in reference to our tender enquiry **GEM/2021/B/1365520 Dated: 17-07-2021** for the subject package, please note the following:

SR NO	Bidder Queries	BHEL Reply
1.	Cu. Lugs has been asked for termination however nothing has been specified of Inline ferrule in Straight through Joint – Kindly confirm whether Al. or Cu. Inline are required in Straight through Joint. Cable specification is mention is of Al. Only.	1) Clause No. 3.6 of Section-I I of technical specification PE-TS-442-507-E009 shall be read as: "Cable lugs/ferrules shall be of Tinned Copper & heavy duty type. Same shall be provided with bimetallic washer." 2) Clause No. 7 Data sheet-A of technical specification PE-TS-442-507-E009 shall be read as: "CABLE UGS/FERRULES(As per DIN): Crimping type solder less Tinned Copper (conforming to IS: 8309) (Heavy duty type)."
2.		The Due date for offer submission & Part-I opening is hereby extended upto 03.08.2021, 03:00 P.M. Techno-commercial offer (Part-I) shall be opened on 03.08.2021 at 03:30 P.M. Kindly Ensure submission/uploading of offer on or before Extended due date & time i.e. by 03.08.2021, 03:00 P.M

**SHASHANK SHEKHAR
ENGR. / PG-III**