



परियोजना
इंजीनियरिंग
प्रबंधन
Project Engineering
Management

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
(भारत सरकार का उपक्रम)
Bharat Heavy Electricals Limited
(A Govt. of India Undertaking)

CORRIGENDUM-01

Ref: PE/PG/YAD/E-6704/2021/Corrigendum/01

Date: 03/08/2021

DUE DATE
13/08/2021
BY 10:00 AM (IST)

Project: 5X800MW YADADRI TPP

Package: NGR

References: Enquiry. No.: PE/PG/YAD/E-6704/2021 Dated 24/07/2021

Subject: Bid submission due date extension & HSN/SAC codes

With reference to the above Tender Enquiry, Bidders to note the following:

- Bidders have to note that HSN/SAC codes for BOQ of subject tender shall be as per Annexure A.
- The due date of Bid Submission for subject tender is extended from existing date 03/08/2021, 10:00 AM (IST) to 13/08/2021, 10:00 AM (IST). Part-I bids shall be opened on 13/08/2021, 4:00 PM (IST).

Thanking You

With regards
For & on behalf of BHEL
Dheeraj Singh
Dy Manager | PG II, BHEL PEM | Noida

Enclosure: Annexure-A

कृपया प्रेषित करें :
बीएचईएल, पीएस-पीईएम
पीपीआई भवन
प्लॉट नं २५, सेक्टर १६ ए
नोएडा - २०१ ३०१ उ प्र
भारत
Please reply to :
BHEL, PS-PEM,
PPEI Building,
Plot No.25, Sector 16A,
Noida-201301 (U.P.)
INDIA
फ़ोन Phone No:
91-120 – 436 8848

पंजीकृत कार्यालय
बीएचईएल हाउस
सीरी फोर्ट
नयी दिल्ली – ११० ०४९
भारत
Registered Office :
BHEL House,
Siri Fort,
New Delhi-110049
INDIA

Annexure-A

S. N.	ITEM CODE.	DESCRIPTION	HSN/SAC Code
1		A. MAIN SUPPLY	
1.1	506-15003-A	11 kV NEUTRAL GROUNDING RESISTOR (22.13 ohm, 300A, 10 SEC.)	85334090
1.2	506-15005-A	3.3 kV NEUTRAL GROUNDING RESISTOR (6.93 ohm, 300A, 10 SEC.)	85334090
1.3	506-15019-A	HOT DIP GALVANISED MS SUPPORTING STRUCTURE WITH INSULATORS, FOUNDATION HARDWARES etc. FOR 11 kV NGR	7308000
1.4	506-15021-A	HOT DIP GALVANISED MS SUPPORTING STRUCTURE WITH INSULATORS, FOUNDATION HARDWARES etc. FOR 3.3kV NGR	7308000
2	506-15018-A	TYPE TEST	
2.1		TEMPERATURE RISE TEST (ON PROTOTYPE) ON 11 KV NGR	85334090
2.2		TEMPERATURE RISE TEST (ON PROTOTYPE) ON 3.3 KV NGR	85334090
3	506-1500-B	MANDATORY SPARES FOR NEUTRAL GROUNDING RESISTOR FOR MAIN PLANT:-	
3.1		BROWN GLAZED PORCELAIN INSULATORS FOR SUPPORTING BETWEEN MOUNTING FRAME AND EACH RESISTOR ASSEMBLY	8533
3.2		INTERPOSING INSULATOR ASSEMBLY	8533
3.3		CERAMIC AND MICANITE INSULATOR FOR SUPPORTING BETWEEN RESISTOR AND MOUNTING FRAME	8533
4	506-1500-B	MANDATORY SPARES FOR NEUTRAL GROUNDING RESISTOR FOR FGD:-	
4.1		BROWN GLAZED PORCELAIN INSULATORS FOR SUPPORTING BETWEEN MOUNTING FRAME AND EACH RESISTOR ASSEMBLY	8533
4.2		INTERPOSING INSULATOR ASSEMBLY	8533
4.3		CERAMIC AND MICANITE INSULATOR FOR SUPPORTING BETWEEN RESISTOR AND MOUNTING FRAME	8533