

Ref: BHE/PW/PUR/BWT6-CVL-MECH-ELE-NDCT/2123/Corg-04

Date: 05/08/2019

To,

ALL BIDDERS,

Sub: Corrigendum-04: Clarifications.

Job: CIVIL, ARCHITECTURAL, MECHANICAL, ELECTRICAL, CONTROL & INSTRUMENTATION WORKS FOR NATURAL DRAUGHT COOLING TOWER (NDCT) AT MSPGCL, 1X660 MW BHUSAWAL THERMAL POWER STATION, UNIT-06, MAHARASHTRA.

References: -

1. E-Tender Specification Nos: **BHE/PW/PUR/BWT6-CVL-MECH-ELE-NDCT/2123**
2. Corrigendum-01 ref. BHE/PW/PUR/BWT6-CVL-MECH-ELE-NDCT/2123/Corg-01 dated 12/07/2019.
3. Corrigendum-02 dated 30/07/2019 for tender due date extension.
4. Corrigendum-03: Out-come of Pre Bid Discussions held on 02/07/2019, 16/07/2019 & 17/07/2019 at BHEL PSWR Nagpur, Amendments and Clarifications

Bidders kindly to take note of the following:

AA) ISSUE OF CLARIFICATIONS AGAINST THE QUERIES:

Sl No	Reference clause of Tender Document	Existing provision	Bidder's query	BHEL's clarification
1	Corrigendum-03, Annexure-B (BOQ), Sr. no. A.4.1	REINFORCEMENT WORK: Transportation from BHEL stores, straightening, cutting, bending, placing in position at all level, binding in position of CRS/HCRM reinforcements of grade Fe-500 confirming to IS:1786 including cost of binding wire, labour, scaffolding, transportation to & from stores etc complete all as per specifications, drawings and as directed by Engineer. (BHEL to supply HCRM/CR steel free of cost)	We presume reinforcement steel required for chairs, spacers, supports which shall be embedded in the concrete shall be measured and paid under this item no. A.4.1.a, b & c. Please confirm.	It is confirmed
2	Corrigendum-03, Annexure-B (BOQ) & Annexure-1, Annexure-A	Thermo-Hydraulic Items : 24. Fills and Fills supporting Arrangement - 14.522700728 (Weightage in %) 25. Distribution System and supporting arrangement - 6.3225746875 (Weightage in %)	We request you to provide us the break-up of Weightage in % mentioned against item no. 24 & 25 in BOQ for calculating the unit rate of items 24.1 to 24.3 and 25.1 to 25.5 mentioned in Annexure-1 of Anexure-A. The same rate shall be considered for quantity variation during execution of work based on the actual quantities. Please consider and confirm.	Tender conditions shall prevail.
3	Corrigendum-03, Annexure-A, Cl. 1.01, 4th paragraph	The NDCT contractor is required to own the owner approved thermal design and GA drawing such that the responsibility of cooling tower performance shall remain with the bidder in all manners. Any questions or clarifications regarding thermal design may be sought by the NDCT contractor to satisfy himself of its veracity.	Since the thermal & structural design of cooling tower is not in the scope of bidder, bidder shall responsible for workmanship & material supplied for the cooling tower. Please consider and confirm.	Tender conditions shall prevail.

Ref: BHE/PW/PUR/BWT6-CVL-MECH-ELE-NDCT/2123/Corg-04

Date: 05/08/2019

4	Corrigendum-03, Annexure-A, Cl. 1.01, last paragraph.	No price implication in the cost of thermo-hydraulic components shall be allowed during execution due to any reason whatsoever from that quoted during tender stage.	This is a Item Rate Contract. We request you to withdraw/delete this paragraph, while following thermo-hydraulic component's BOQ based on BHEL's design as per Annexure-1 of Annexure-A in corrigendum-03. We request you to allow for Variations in quantities and cost of all the items of BOQ including thermo-hydraulic components. Please consider and confirm.	Tender conditions shall prevail.
---	--	--	--	----------------------------------

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → www.bhel.abcprocure.com

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

AGM (Purchase)