



भारत हेवी इलेक्ट्रिकल्स लिमिटेड
Bharat Heavy Electricals Limited
उद्योग क्षेत्र, नई दिल्ली / Industry Sector, New Delhi
मानव संसाधन प्रबंध / Human Resources Management

CORRGENDUM-1

REF. NO. ID/Pur/0910/Precision AC /2014-15/02

Dated 24.01.2015

PLEASE REFER OUR OPEN TENDER ENQUIRY REF. NO. ID/Pur/0910/Precision AC /2014-15/01
Dated 05.01.2015 DUE FOR OPENING ON 27.01.2014

REFER TECHNICAL SPEC. REF NO IS-TS-001 ATTACHED WITH ENQUIRY DOCU.. THERE IS A AMENDMENT IN THIS SPEC. WHICH IS- ADDITIONAL REQUIREMENT OF INSULATION IN FLOORING IS TO BE INCLUDED IN YOUR SCOPE OF SUPPLY.

1) INSULATION IN FLOORING

The floor of the server room(25X 14 feet) is to be insulated with 16mm thick class "O" Nitrile insulation to avoid condensation in the true ceiling below the floor. The floor grill for outlet of cold air is under the scope of vendor. Accordingly price format is also to be updated.

2) THE ENQUIRY OPENING DATE IS HEREBY EXTENDED UP TO 10.02.2015

OPEN TENDER ENQUIRY REF. NO. ID/Pur/0910/Precision AC /2014-15/01 Dated 05.01.2015.

Bids should be submitted as per clause 1 of Terms and Condition, Annexure-1 attached with enquiry docu.. Bids Complete in all respects should reach our office on or before 10/02/2015 up to 02.00 PM. **Un-Priced Bid** will be opened at 15-30 Hrs on the same day.

In all other respects the terms and conditions of the enquiry remains unaltered.

P. K. Khandelwal

Deepak Khandelwal

Revise price format to be uploaded

Shreyas



AMENDMENT INTECHNICAL
REQUIREMENT
AIR CONDITIONING SYSTEM
SERVER ROOM – 4TH FLOOR, IS, LODHI
ROAD BUILDING

BHEL Doc No: IS-TS-001

REV

00



DATE

24.1.2015

SERVER ROOM – 4TH FLOOR,
IS, LODHI ROAD BUILDING
N.DELHI

AMENDMENT - TECHNICALSPECIFICATION

AIR-CONDITIONING SYSTEM

TITLE	AMENDMENT TECHNICAL SPECIFICATION OF PRECISION AC FOR SERVER ROOM – INDUSTRY SECTOR	
PREPARED BY	Amit Kumar Nag	
APPROVED BY	Manish Kumar Garg	



**AMENDMENT INTECHNICAL
REQUIREMENT
AIR CONDITIONING SYSTEM
SERVER ROOM – 4TH FLOOR, IS, LODHI
ROAD BUILDING**

BHEL Doc No: IS-TS-001

REV

00

DATE

24.1.2015

With reference to specification of Precision AC for server room, one addition specification has to be considered as per below mentioned clause. All other specifications are as per previous clauses

1. INSULATION IN FLOORING

The floor of the server room (25X14 ft) is to be insulated with 16mm thick class 'O' Nitrile insulation to avoid condensation in the true ceiling below the floor. The floor grill for outlet of cold air is under the scope of vendor.

Amway

Sr.DGM (P&MS) *Alavir*

PRECISION AC FOR SERVER ROOM - INDUSTRY SECTOR, LODHI ROAD, NEW DELHI
SUGGESTIVE PRICE FORMAT

Rev 00 Dated 24-1-2015

Clause No.	DESCRIPTION	Qty.	Unit	SUPPLY					ERECTION & COMMISSIONING			TOTAL	
				Unit Price (Rs)	Total Bn-works price (Rs)	ED including CRSS (Rs)	CST / VAT (Rs)	FREIGHT Including Service Tax, if applicable (Rs)	TOTAL F.O.B. Site Price Supply (Rs)	UNIT PRICE (Rs)	Total Price (Rs)		Service Tax (Rs)
1	LUMP SUM PRICES												
	Total lump sum firm prices for Equipment & Services as Specified, including design, manufacture, inspection & Testing at manufacturers works, Packing at manufacturers works, duly packed for transportation, delivery to site, unloading storage & handling at site, erection & commissioning, carrying out acceptance tests at site & final painting of air cooled Precision type AC units of Minimum 5.5 TR capacity consisting of condensing unit, evaporating unit including refrigerant pipes & fittings with insulation, humidifier and accessories as per Specification (S-75-001) including all taxes, duties, Insurance of server room floor, floor grill etc.	2	Set										