

Corrigendum – 10. dated 23/06/2025 to CPC Tender No. BHEL/CPC/EPC BOP/SNG/26/009

Name of Work:

EPC PACKAGE FOR BALANCE OF PLANTS (BOP) AT 1 X 800 MW SINGARENI SUPER THERMAL POWER PROJECT, STAGE - II, MANCHERIAL, TELANGANA

A) Time Extension: Clause No. 1.0 Salient Features of NIT in NOTICE INVITING TENDER is revised as below:

Sl. No.	Clause No.	Existing in Tender	Revised Vide Corrigendum-1	Revised Vide Corrigendum-2	Revised Vide Corrigendum-3	Revised Vide Corrigendum-4	Revised Vide Corrigendum-9	Revised As
1	Sl. No. v) DUE DATE & TIME OF OFFER SUBMISSION.	Date: 16/05/2025, Time: 10:00 Hrs	Date: 23/05/2025, Time: 10:00 Hrs	Date: 30/05/2025, Time: 10:00 Hrs	Date: 06/06/2025, Time: 10:00 Hrs	Date: 16/06/2025, Time: 10:00 Hrs	Date: 23/06/2025, Time: 10:00 Hrs	Date: 26/06/2025, Time: 10:00 Hrs
2	Sl. No. vi) OPENING OF TENDER	Date: 16/05/2025, Time: 16:30 Hrs	Date: 23/05/2025, Time: 16:30 Hrs	Date: 30/05/2025, Time: 16:30 Hrs	Date: 06/06/2025, Time: 16:30 Hrs	Date: 16/06/2025, Time: 16:30 Hrs	Date: 23/06/2025, Time: 16:30 Hrs	Date: 26/06/2025, Time: 16:30 Hrs

B) Replies to Bidder's queries as mentioned below:

Sl No.	Existing Clause	Query	BHEL Reply
1.	Reference clause of Tender Document - Water Treatment System	Please provide the raw water analysis and clarified water analysis for the design of Water Treatment Plant (WTP).	Please note that the raw water analysis is already provided in tender specification Section VI, Part -A , sub section -IB, project information , Annexure -III. (Refer Tender Document Part3, 1D_Volume D Book 2 of 5 Page 674/995) Further clarified water analysis shall be arrived as per the dosing rate specified in Pre-Treatment Plant specification (

Corrigendum – 10. dated 23/06/2025 to CPC Tender No. BHEL/CPC/EPC BOP/SNG/26/009

Sl No.	Existing Clause	Query	BHEL Reply
			Refer Alum & lime Dosing rates as specified in tender specification clause section VI, Part -B, sub -section A-14 clause 20.02.00 sr. no. 10 to be considered , PE dosing rate to be considered @ 2ppm and chlorine dosing rate to be considered @5 ppm for arriving clarified water analysis) (Refer Tender Document Part2, 1C_Volume D Book 1 of 5, Page 471/1137)
2.	Reference clause of Tender Document - GCC - 1.9.1 // ii – In case EMD amount is more than Rs. Two Lakhs, Tenderer has the option to submit the amount in excess of Rs. Two lakhs in the forms described above in clause no. 1.9.1. ii) (a) to (e) or in the form of Bank Guarantee from Scheduled Bank (along with the Offer). The Bank Guarantee in such cases shall be valid for at least six months from the due date of tender submission. The Bank Guarantee format for EMD shall be in the prescribed formats.	Total EMD is Rs. 50 Lakh. 1.Please confirm that Rs. 2 Lakhs of EMD to be paid mandatory in form of cash (DD/Chq/NFT/FDR/Surety Bonds) and Balance portion i.e Rs. 48 Lakh can be submitted in the form of BG 2.Also can we submitted Total EMD (Rs 50 Lakh) in Surety Bonds. Please clarify	1. As per Clause No. 1.9 of the General Conditions of Contract (GCC), in case the EMD is being submitted in any form other than Insurance Surety Bond (e.g., DD/Cheque/NEFT/FDR/Bank Guarantee), a minimum cash deposit of ₹2 Lakh is mandatory. The balance amount (i.e., ₹48 Lakh) may be submitted in the form of a Bank Guarantee or other acceptable instruments, as specified. 2. However, if the EMD is being submitted entirely in the form of an Insurance Surety Bond, the entire amount of ₹50 Lakh can be submitted in this form without the requirement of any cash deposit

Note:

- 1) All other terms and conditions against this NIT shall remain unchanged.**
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).**

**for BHARAT HEAVY ELECTRICALS LTD
Sr. Manager/ SCT- CPC**