

Ref: BHE/PW/PUR/BWT6-CVL-MECH-ELE-NDCT/2123/Corg-11

Date: 11/09/2019

To,

ALL BIDDERS,

Sub: Corrigendum-09: Clarifications.

Job: CIVIL, ARCHITECTURAL, MECHANICAL, ELECTRICAL, CONTROL & INSTRUMENTATION WORKS FOR NATURAL DRAUGHT COOLING TOWER (NDCT) AT MSPGCL, 1X660 MW BHUSAWAL THERMAL POWER STATION, UNIT-06, MAHARASHTRA.

References: -

1. E-Tender Specification Nos: **BHE/PW/PUR/BWT6-CVL-MECH-ELE-NDCT/2123**
2. Corrigendum-01 ref. BHE/PW/PUR/BWT6-CVL-MECH-ELE-NDCT/2123/Corg-01 dated 12/07/2019.
3. Corrigendum-02 Dated 30/07/2019 for tender due date extension.
4. Corrigendum-03 Dated 01/08/2019: Out-come of Pre Bid Discussions held on 02/07/2019, 16/07/2019 & 17/07/2019 at BHEL PSWR Nagpur, Amendments and Clarifications
5. Corrigendum-04 Dated 05/08/2019 for Clarifications
6. Corrigendum-05 Dated 12/08/2019 for tender due date extension
7. Corrigendum-06 Dated 17/08/2019 for Clarifications
8. Corrigendum-07 Dated 20/08/2019 for Change of IEMs
9. Corrigendum-08 Dated 26/08/2019 for tender due date extension
10. Corrigendum-09 Dated 04/09/2019 for Clarifications
11. Corrigendum-10 Dated 09/09/2019 for tender due date extension

Bidders kindly to take note of the following:

AA) ISSUANCE OF CLARIFICATIONS AGAINST THE QUERIES FOR CORRIGENDUM-01: -

Sl No	Reference clause of Tender Document	Existing provision	Bidder's query	BHEL's clarification
1	As per Clause No. 1.0, Vol-II B, Sec-C of Electrical Equipment Specification	Supply of Spares	The mandatory spares & commissioning spares as specified in the specifications of mechanical equipment are to be provided by the bidder however the list of the same is not mentioned in the BOQ - Kindly clarify.	It is clarified that as per technical specification, Mandatory spares are not applicable and commissioning spares are on as required basis.
2	As per Clause No. 2.01.05, Section-I, Sub-section-IA Vol-II B, Sec-C of Technical	Supply of Spares	Supply of commissioning spares and mandatory spares as specified in the technical specifications are in the scope of the bidder, however the list of the same is not mentioned in the BOQ - Kindly clarify.	

Ref: BHE/PW/PUR/BWT6-CVL-MECH-ELE-NDCT/2123/Corg-11

Date: 11/09/2019

Sl No	Reference clause of Tender Document	Existing provision	Bidder's query	BHEL's clarification
	Specification			
3	Clause No 4.7.20.18 (y) of Section-I of Volume VI-A	PVC film fills are required to be with 0.25 mm uniform thickness and double edge folding.	BHEL is requested to consider the PVC Film Fills with 0.25 mm uniform as well as average thickness and with double edge folding as well as with straight edge.	It is clarified that fill film thickness can be considered as 0.25 mm average thickness (after forming). However, the minimum thickness shall not be less than 0.23 mm (after forming).

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → www.bhel.abcprocure.com

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

AGM (Purchase)