



BHARAT HEAVY ELECTRICALS LIMITED

IVP GOINDWAL SAHIB

MM DEPARTMENT

Date: 30.09.2015

Corrigendum

Reference:

1. *Tender Enquiry no. 1516-086 Dated 12.09.2015*
2. *Item description: “Electrical Insulating Mat for electrical purposes”.*

With ref. to above tender enquiry, following changes has been made:

1. Technical specification of item Sl. No. 02 of tender enquiry i.e., “ELECTRICAL INSULATING MAT, WV- 11.0 kV (GWT67014120)” has been revised as per below:

Working voltage	11 KV
Proof voltage	22 KV
Break down voltage / Di-electric strength	45 KV
Minimum thickness	2.5 mm
Surface	Minute abrasions on upper surface of mat to make surface anti-skid
Size	Standard width 01 metre & length 02 metre

2. Due date of quotation submission date has been extended up to **15.10.2015 at 1500 Hrs.** Quotations will be opened on **15.10.2015 at 1530 Hrs.**

Except above two points, all the other tender terms & conditions will remain unchanged. Please submit your quotation, considering the above.