

**Corrigendum - 2 dated 05/08/2024 to CPC Tender No. BHEL/CPC/SGL/MPH-CVL/25/023**

**Corrigendum - 2 dated 05/08/2024 to CPC Tender No. BHEL/CPC/SGL/MPH-CVL/25/023** for the work of “CIVIL AND ARCHITECTURAL WORKS IN FOUNDATIONS & CIVIL SUPERSTRUCTURE FOR MAIN POWER HOUSE BUILDINGS, TG DECKS, COMMON CONTROL ROOM, SERVICE BUILDING, TRANSFORMER YARDS, SWITCHYARD, PIPE/CABLE RACK FOUNDATIONS & MISC. BLDGS. OF UNIT-1 AND UNIT-2 FOR 2X800 MW SINGRAULI STPP STAGE-III, DISTRICT SONEBHADRA, U.P.”.

A) **Time Extension:** Clause No. 1.0 Salient Features of NIT in NOTICE INVITING TENDER is revised as below:

Sl. No.	Clause No.	Existing in Tender	As per Corrigendum - 1	Revised As
1	Sl. No. v) DUE DATE & TIME OF OFFER SUBMISSION.	Date: 29/07/2024, Time: 10:00 Hrs	Date: 05/08/2024, Time: 10:00 Hrs	<b>Date: 08/08/2024, Time: 10:00 Hrs</b>
2	Sl. No. vi) OPENING OF TENDER	Date: 29/07/2024, Time: 16:30 Hrs	Date: 05/08/2024, Time: 16:30 Hrs	<b>Date: 08/08/2024, Time: 16:30 Hrs</b>

B) **Modification in BOQ CUM RATE SCHEDULE ITEMS:**

BOQ ITEM NO.	Clause as per Corrigendum-1	Revised Clause
	<b>Description</b>	<b>Description</b>
1814B	Installing of 40 mm diameter Rod Electrode with test pit/link per approved drawing including following works : - excavation - installing the rod electrode - backfilling and compaction - Casting the Test Pit with Cast Iron covers - any other work necessary to complete the work <b>Note: Only 40 mm Diameter MS rod &amp; test link shall be issued by BHEL free of cost, other items like CI frame, cover etc.</b>	Installing of 40 mm diameter Rod Electrode with test pit/link per approved drawing including following works : - excavation - installing the rod electrode - backfilling and compaction - Casting the Test Pit with Cast Iron covers - any other work necessary to complete the work <b>Note: Only 40 mm Diameter MS rod &amp; test link shall be issued by BHEL free of cost, other items like CI frame, cover etc. shall be supplied by contractor.</b>

**Corrigendum - 2 dated 05/08/2024 to CPC Tender No. BHEL/CPC/SGL/MPH-CVL/25/023**

**C) Clarifications issued by BHEL are furnished below:**

Sl.	Reference tender clause no.	EXISTING PROVISION	Bidder's query	BHEL reply/clarification
1	TCC Clause 1.6 & Annex 1 (Chapter XII)	For TG Foundation Civil Works: Successful bidder shall submit the following credential.....	We understand that this form has to be submitted by successful bidder only. Kindly confirm.	Please refer PQ criteria, 'Explanatory Notes for the PQR', Sl. No. 10 which stipulates as follows: 'Bidder shall submit a confirmation/declaration as per Annexure-I of Chapter-XII of TCC in line with Clause 1.6 of TCC along with bidding documents.' In view of above, all bidders need to submit the confirmation/declaration as per Annexure-I.
2	Weightage of BOQ CUM RATE SCHEDULE ITEM No. 2307 (a)	% WEIGHTAGES OF BOQ ITEMS- 0.14921562052	In Item No.- 2307 (a) percentage of weightages should be 3.0	Please refer Corrigendum- 1, Dated 29/07/2024. Tender specifications to be followed.
<b>Note:</b>				
1	<b>Reply to the queries is for bidders information only and it shall not have any effect on terms and conditions of tender.</b>			

**Note:**

- 1) All other terms and conditions against this NIT shall remain unchanged.
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).

**for BHARAT HEAVY ELECTRICALS LTD  
Manager/ SCT**