



Bharat Heavy Electricals Limited
Transmission Business Group
Tower A, 5th Floor, Advant Navis IT Business Park,
Plot No. 7, Sector-142, Expressway, Noida-201305
Distt. Gautam Buddha Nagar, U.P
Phones: 0120-6748480, Fax: 0120-6748581

SUBJECT- CORRIGENDUM TO NIT No.29521 / ENQUIRY No.156E167

1. Project : KPCL Yelahanka
2. Equipment / Item : 220kV Isolators
3. Enquiry No. / Date : Enquiry No.156E167 dtd.23.09.16


With reference to the above tender, please refer following-

1. Please note following technical details-

- A) Operating mechanism of Isolator & Earth switch shall be motor & manual operated in line with sl no. 2.6, cl no. 1.2, Section-1 of Tech spec no. TB-379-316-002. Sl no. 20, Section-5 (Checklist) of specification may be read accordingly.
- B) Moving contact assembly arm shall be of "Aluminium" design.

2. Tender due date has been extended to 21.10.2016.

All other terms and conditions of tender shall remain same. Kindly ensure submission of your offer by due date.


(Gaurav Agarwal)
Sr. Engineer (TBMM)