



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)

**Project Engineering
Management**

4 X 111 MW VISHNUGAD PIPALKOTI HEP - OPEN TENDER ENQUIRY FOR 2 NOS. 150/50/10T D/G EOT CRANE FOR POWER HOUSE, 1 NO. 150/50T D/G EOT CRANE FOR BUTTERFLY VALVE AREA AND 1 NO. 12T SINGLE GIRDER EOT CRANE FOR GIS HALL

Ref No. : PE/PG/TH1/E-5380/2016

Date: 26.10.2016

CORRIGENDUM/ ADDENDUM-1

Tender Enquiry no.: PE/PG/TH1/E-5380/2016
Date: 17.11.2016

Extended DUE DATE
22 Nov 2016
10:00 AM

Sir,

- 1) Kindly note that the due date of tender opening of above said package is hereby extended up to 22.11.2016. Offer received by 10.00 AM on 22.11.2016 and part – I bid shall be opened at 11.00 AM on 22.11.2016. Please submit the offer in Tender Room formed behind reception desk of PEM office. **Please ensure submission of offer by or before extended due date & time i.e.**

22 Nov 2016 10:00 AM.

- 2) Please find below the reply of Pre-Bid query asked by bidders.

Please note that there are two number of 150/50/10 T Power house cranes. In both the cranes, the orientation of main hook and auxiliary hook is mirror image to each other. The same has been indicated in the key plan. In view of this, the orientation of the hooks on the bridge girder as indicated in 'View – X' is indicative only. Approaches required for Main and auxiliary hook required for both the cranes have already been indicated in 'View-X' as well as 'Key Plan' (to be read in conjunction with each other) of CCD.


In view of this, there is no ambiguity in crane clearance diagram of Power House crane furnished along with tender enquiry.

The bidders who have already submitted their bids for the said tender enquiry, may go through the corrigendum and in case it is felt required, may furnish revised bid with envelopes duly superscribed as **"Revised bid (only to be considered)"**

All bidders are requested to visit BHEL websites www.bhel.com (Tender Notifications Section) OR www.bhelpem.com (http://www.bhelpem.com/Tenders_Rev/NewTenders.aspx), all future corrigendum, addendums, amendments, if any, for this tender shall be hosted only on above websites.

Thanking you,

Yours faithfully,
For and on behalf of BHEL


TARUN ARYA
(Sr. Engineer/Project Group-1-1)

Please reply to:
Tarun Arya-Sr.Engr. / Abhishek Pandey, Dpty. Engineer
PGI-I

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No. 0120-4368791/4368739