

Corrigendum

With reference to tender enquiry No. 1213-028 Dt. 07.05.2012 for supply of machined castings to BHEL, Goindwal, the corrigendum is mentioned below:

1. Please refer Prequalification Terms point No. P1 [B]- Machining House:

Please note that foundry(ies) to which machining house has tie-up/MoU should have minimum spare capacity-10 MT/month. **Machining house has to give undertaking mentioning that minimum-10 MT/month can be supplied after development of patterns as per the load given by BHEL.**

The above conditions has to read along with other terms and conditions already mentioned.