



BHARAT HEAVY ELECTRICALS LIMITED

HEAVY POWER EQUIPMENT PLANT

RAMACHANDRAPURAM, HYDERABAD – 502 032.

FAX NOS: 0091 (0) 40 -2318 6113, PHONE NO. : 0091 (0) 40 – 2318 4259,

PURCHASE DEPARTMENT – CAPITAL GOODS

CORRIGENDUM & EXTENSION OF DUE DATE

REF: M2/12/6000001651/VK1

DATE: 29.08.2012

Sub: **Corrigendum & Extension of tender due date** – intimation – Reg.

Ref: Our Enq. No. M2/12/6000001651/VK1, DT: 04.08.2012

With reference to our tender enquiry cited, **it is to inform you following amendments were made in the specification.**

Sl.No	Clause No.	Existing	Amendment
1	Clause 8.2 of specification	Voltmeters and Ammeters provided shall be of class 1.5 accuracy and size 96 X 96 MM	Voltmeters and Ammeters accuracy class shall be 1.0 and size 96 X 96 MM
2	Clause 8.3 of technical data sheet	Quantity & Rating- Total 3 outgoing feeders 1 no. 3200A and 2 Nos. 2000A breakers	Total outgoing feeders – 4 Nos. 2Nos 3200A and 2 Nos 2000A breakers

we request you to submit your offer considering the above changes. The due date for submission of your quotation is hereby extended till **20.09.2012.**

You are requested to submit your quotation to reach the undersigned on or before **20.09.2012** by 11.00 A.M. without fail.

Thanking you,

Note:

- 1. If you have already submitted your offer, please submit revised offer considering the above mentioned changes.**
- 2. All other clauses of specifications and Terms & Conditions remain unchanged.**
- 3. You have to submit “Regret Letter”, if you are not participating in this tender. Otherwise you will be evaluated your performance and you will not be considered for future enquiries.**

Yours faithfully,

Venkatesh.M,
Officer/Pur-CG,
BHEL, RC Puram,
Hyderabad - 502032