



Project: NTPC Patratu STPS (3 X 800 MW)

**CORRIGENDUM
NO. 5 dt.
29.03.2022**

**Machine Package (Package A)-Bucket
Wheel Stacker cum Reclaimer
3X800MW PVUNL, Jharkhand State**

**Tender Ref. No.
Enquiry No.
77/21/6111/JRK Dated
14-02-2022**

Please note the following point

Sl. No.	Event Description	TO NOTE
1	Techno-commercial	Corrigendum issued for the following: 1. Technical clarification issued.
2	All other terms & conditions	Remain unchanged.

Note:

Also, please note that the full tender document can be downloaded from the website
<https://eprocurebhel.co.in/nicgep/app>

Contact Person:	
Technical-	Sandeep Sadu Dy. Manager/ Engineering (Mech) E-MAIL: ssd@bhel.in Ph. No. +91-080-2218 4219
Commercial-	J.R.Sumanjali.K., Manager/ Purchase E-MAIL: jrk@bhel.in Ph. No. +91-080-2218 4314 Shabeer Dewan, DGM/ MM EMAIL: sbd@bhel.in Phone:- +91 80 2218 4585

All other terms and conditions remain the same as per the original enquiry and it's subsequent amendment / addendum / corrigendum /clarification.

Any further addendum / corrigendum/ clarification/ notice of due date extension such issued shall be part of the bidding documents and this will be available at the web site from where the original documents have been received / downloaded by the bidder.

Hence bidders are requested to visit the web site on regular basis.

Tender Ref: 77/21/6111/JRK dated 14.02.2022 Published for "Main STACKER CUM RECLAIMER Package"

3X800MW PATRATHU TPS, JHARKHAND

Technical clarification dated 29-3-2022					
Sl. No.	Document	Clause No.	Heading / Title	Comments	BHEL reply
1	IS-1-17-2005/SCR/PKG-A-RE	L, a	MVWS fire protection for Boom conveyor and Tripper shall be in the scope of BHEL- PE&SD. However, successful bidder shall keep provision for MVWS for fire protection in the machines and will submit all necessary inputs required by BHEL PE &SD/ their vendor	<p>Bidder like to understand is there any fire water pumps & tanks are placed on the machine.</p> <p>If yes, then client to furnish the space requirement and load data for MVWS system.</p>	<p>1) Space required on stacker cum reclaimer machine for BHEL PESD's equipment – 1.5 M x 2.5 M x 2.0 M</p> <p>2) Equipment: DV Control station arrangements (Piping & Valves) - 150 Kgs. Note:- In addition, a pipe will run along the conveyor with the load of 50 Kg/m</p> <p>Bidder to keep provision for above in his stacker-cum - reclaimer machines.</p>