

TENDER SPECIFICATION

BHEL: PSSR: SCT: 1436

FOR

Handling at Site Stores / Storage yard, Transportation to Site of Work, Erection, Testing and Commissioning and completion of trial operation of Boiler & Aux, Rotating Equipments including supply and application of final painting for Unit- 1&2 of 2 x 525 MW sets

at

**Malibrahmani Thermal Power Project,
Angul, Orissa**

CORRIGENDUM

DATED: 24/03/2011



BHARAT HEAVY ELECTRICALS LIMITED

(A Government of India Undertaking)

Power Sector – Southern Region

690, Anna Salai, Nandanam, Chennai – 600 035

CORRIGENDUM TO TENDER NOTICE SCT 1436**TENDER SPECIFICATION NO BHEL: PSSR: SCT: 1436**

1. Clarifications sought by the bidders in the Tender Specification BHEL PSSR SCT 1436 vide letter and in the Pre Bid Meeting on 24/03/2011 at BHEL PSSR are furnished below for your information.

Tender Ref Clause	Bidder's query	BHEL Clarification
Vol 1A Part II Ch 8 Final Painting	Please furnish the final painting DFT	Final painting DFT including shop painting should be minimum 140microns.
General	Please furnish the distance between storage yard and erection site	Within 1km in plant premises
CL 1.3.9.1(b) on page 26 of vol 1A(TCC)- Drawing for construction method in BHEL as well as bidder scope	Please confirm which type of construction drawing shall be prepared by bidder	Drawings required for Pre assy/ Erection purpose shall be prepared by the bidder from the BHEL supplied Construction drawings.
CL 1.6.4 contract period on page 33 of vol 1A(TCC)- Contract period for completion work is given as 28 months for each unit	Please confirm the phase gap between two units	3 months
Serial no 1.3.9.1 .k. on page 27 of vol 1A TCC- Lying of racks (it should be TRACK) for Gantry cranebidder himself	We understand that supply of material and gantry crane is in the scope of BHEL. Please confirm	This clause is not applicable to this tender
CL 1.4.1(Note 2 on page 31 of vol 1A TCC a) In the event of providing BHEL crane b) B) In the event of providing hired cranes	a) Please confirm that the operator is provided by BHEL free of cost or on chargeable basis, if on chargeable basis then confirm the monthly charges b) Please confirm who has to provide crane operator, if by agency then what is the monthly charges or shall be free of charges	Refer the note 2 of CL 1.4.1 in Vol 1A TCC.BHEL will provide operator on free of charges for the cranes in BHEL scope.

<p>Note-1 line -2 of Vol 2 price bid The quoted rates shall be applicable any add product group of manufacturing unit, if included.....Accepted by BHEL</p>	<p>This needs to be elaborated as if a product group of P-91 material is included, the same cannot be done at the quoted rate</p>	<p>Refer the welding schedules vol 1 part 2 Annexure 2 for the applicable pressure parts materials for this package.</p>
<p>CI 4.1.4 on page 7 of SCC ch IV –under heading, it is mentioned filler wires for electrodes for P91/T91</p>	<p>It should be filler wire AND electrodes for P91/T91 piping</p>	<p>Refer CL 27.0 order of precedence in NIT and CL 1.3.10.4.2 for facilities in the scope of bidder/BHEL</p>
<p>CL 2.3.9 of CH-3 on page 50 of TCC-some platform materials in PG35 and 36within quoted rate</p>	<p>Please confirm the approx tonnage which is to be fabricated</p>	<p>Meager Quantity hence it cannot be indicated.</p>

Please visit www.bhel.com to view corrigendum

ALL OTHER CONDITIONS AND DUE DATE OF TENDER SUBMISSION REMAIN UNCHANGED.

**AGM / CONTRACTS
BHEL/PSSR/CHENNAI**