

Dt. 27.01.2021

Enq No **352001361** Dt. **16.01.2021**

Details of corrigendum

Sl.No.	BHEL Specification	FOR	Read
1	Sl.No.4.4 of PSGSG/20-21 /001, Core Type III (Protection), Class	5P20	PS
2	Item Description, Sl. No. 3 (Page 1 of 23)	245kV CT Protection core 2500-1250 / 1, 5P20	245kV CT Protection core 2500-1250 / 1, PS
3	Item Specification, Sl. No. 3 (Page 12 of 23)	245kV CT Protection core 2500-1250 / 1, 5P20	245kV CT Protection core 2500-1250 / 1, PS
4	Enquiry and Qualifying criteria, Sl. NO. 2, Item Description – Qty, Item 3 (Page 2 of 23)	245kV CT Protection core 2500-1250 / 1, 5P20 - 4 NO	245kV CT Protection core 2500-1250 / 1, PS - 4 NO
5	Due date	06.02.2021	11.02.2021

Ajay Kumar Muske
Dy Manager (Purchase)