

Corrigendum for Enquiry No : E4803023 for 200KVA DG sets

Tender Specification No OR12695 Rev 03


Following Clause to be read as follows :

Warranty Clause No 15.1 (Part-I)

- 15.1** Supplier will warranty the products to be free from defects in materials and workmanship and to comply with specification and intended use. The supplier will provide warranty for a period of 30 months from the date of dispatch or 12 months from the date of commissioning at OIL Duliajan site or **5000 Running hours whichever is earlier**. The warranty applies to all supplier manufactured and supplied components.

Supplier shall furnish full contact details for giving warranty calls, as per format provided in Annexure-5, and shall ensure that their engineer/ representative reaches site fully prepared within 48 hours of warranty call. If required Supplier/ it's authorized representative, will be available for warranty calls at Supplier's account.

Free scheduled maintenance to be provided by OEM of Engine / their authorized service provider at OIL Duliajan Site as per Engine OEM recommended maintenance schedule & procedure during warranty period. **Spares & Consumables required during free scheduled maintenance shall be in the scope of bidder considering for 2000 Running hrs of DG sets. Such Spares and Consumables kit to be carried by Service personnel of OEM of Engine/Authorised Service agent during each scheduled maintenance.**


23/09/2020

Praveen Shah

Dy. Manager-CEE

AGM-CEE  23-09-2020