



CORRIGENDUM TO GEM/2026/B/7300723 Dated: 05-03-2026

Item : Supply and Supervision of ETC for 400 kV & below rating Isolators for RPPTL
(AESL) HVDC BF800
GeM Tender : GEM/2026/B/7300723 Dated: 05-03-2026
ID
BHEL NIT : NIT_98244
Enquiry : Open Tender (Through GeM)

S.no.	Section-2 TECHNICAL SPECIFICATION NO. TB-442-316-007 FOR ISOLATORS	Clarification/Amendment
1	Clause: 5.0 (b)	Common marshalling box- deleted. No change in other requirements against this clause. Bidder are required to quote accordingly.
2.	Clause: 5.0 (m)	Deleted Bidder are required to quote accordingly.
3.	Clause: 5. (n)	Plug-in type terminals block shall be used. Bidder are required to quote accordingly.

Tender due date submission is extended up to **15.04.2026**.