

Ref No. : PE/PG/PA1/E-6753/2021 /CORRIGENDA/05

Date: 06.10.2021

**CORRIGENDA / ADDENDUM-05**

**SUBJECT: HEAT EXCHANGERS (PLATE TYPE) for 3 X 800MW PVUNL PATRATU TPP PHASE-I PROJECT (434) as per Technical Specification No. PE-TS-434-179-N002(REV00).**

**OUR REF: TENDER ENQUIRY NO: PE/PG/PA1/E-6753/2021 DTD.24.08.21**

DUE DATE
16/10/2021
BY 11:00AM

1. Amendment-01 to Technical Specification no. PE-TS-434-179-N002(Rev00) is enclosed with this corrigendum and bidders to comply the same in their bid/offer.
2. The last date of submission of offer against tender of **HEAT EXCHANGERS (PLATE TYPE)** invited vide Enquiry No PE/PG/PA1/E-6753/2021 DTD.24.08.21 has been extended till **16.10.2021, 11.00AM**. Part I Bid opening will be done on **16.10.2021, 04.00PM**. All bidders are requested to visit the <https://pem.bhel.com/> , & [www.bhel.com](http://www.bhel.com) & <https://eprocurebhel.co.in/nicgep/app> websites . All future corrigenda/ amendment and due date extension, if any, for this tender shall be hosted only on above websites.

Thanking You,

With Regards,

For & on behalf of BHEL

HEMANT KUMAR  
KAUSHIK

Digitally signed by HEMANT KUMAR KAUSHIK  
DN: cn=IN, o=BHARAT HEAVY ELECTRICALS LIMITED, ou=BHEL  
PS PEM Noida, postalCode=201301, st=UTTAR PRADESH,  
2.5.4.29=2236963953689898985714143a3996fd344e71df65  
ba485174ba5f7654815ce,  
serialNumber=ba383a9c26a5df2db2a74c2aeb36743A454b7f8  
42d4041b25fa6a51f532be80a18, cn=HEMANT KUMAR  
KAUSHIK  
Date: 2021.10.05 18:29:48 +05'30'

Hemant Kr Kaushik

MGR/PGIII

Please reply to:

**Hemant Kr Kaushik**

**MGR/PGIII**

Power Project Engineering Institute Building  
HRD & ESI Complex Plot No. 25, Sector -16 A,  
BHEL-PEM,Noida-201301 (U.P.)  
Tel No.0120-4213549 , 09540180895

**PATRATU SUPER THERMAL POWER  
STATION EXPANSION PHASE-I (3X800MW)**

HEMANT KUMAR  
KAUSHIK


1. This document is the property of Bharat Heavy Electricals Limited. It is to be used only for the purpose for which it is issued and is not to be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of the Director, Planning & Design, BHEL, Patratu.

**AMENDMENT NO. 1  
TO TECHNICAL SPECIFICATION  
FOR  
PLATE HEAT EXCHANGERS**

**Specification No. : PE-TS-434-179-N002 (REV 0)**



**BHARAT HEAVY ELECTRICALS LIMITED  
POWER SECTOR  
PROJECT ENGINEERING MANAGEMENT  
PPEI BUILDING, SECTOR 16 A  
NOIDA - 201301**

	TECHNICAL SPECIFICATIONS PHE	SPECN. NO.:	PE-TS-434-179-N002		
	AMENDMENT NO. 1	REV. NO.	0	DATE:	05.10.2021

<b>1.0</b>	With reference to Datasheet A, Section ID of Technical Specification, please consider the Specification amended as below, <b>only for PHE FOR ECW-COMMON STATION AUX.:</b>	
<b>S.No.</b>	<b>Clause as mentioned in Technical Specification</b>	<b>Ammended Clause</b>
1.7	Maximum permitted Length of the PHE: 6000 mm (excluding reducer)	Maximum permitted Length of the PHE: <b>6600</b> mm (excluding reducer)

HEMANT  
KUMAR  
KAUSHIK

Digitally signed by HEMANT KUMAR KAUSHIK  
 DN: c=IN, o=BHARAT HEAVY ELECTRICALS LIMITED, ou=BHEL PS PEM Noida, postalCode=201301, st=UTTAR PRADESH, 2.5.4.20=2036963903686989b857141c4a3a96f3d34ee71df65ba485176ba5f765d615ce, serialNumber=b8383a9c26a60f2dba74c0aeb387434454bf7842d4041b5fa6a51f532be80a18, cn=HEMANT KUMAR KAUSHIK  
 Date: 2021.10.05 18:32:06 +05'30'