

**RAJASTHAN RAJYA VIDYUT UTPADAN NIGAM
LIMITED**

2X660 MW SURAHGAH STPS, STAGE-V , UNIT -7 & 8

***TECHNICAL SPECIFICATION FOR
220V DC BATTERY***

BHEL DOCUMENT NO. : PE-TS-392-508-E001, REV-0



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA – 201301**



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 1 OF 31

CONTENTS

<u>S. NO.</u>	<u>CONTENTS</u>	<u>NO. OF SHEETS</u>
01	INSTRUCTIONS TO BIDDERS	01
02	DEVIATION SCHEDULE	01
03	PREAMBLE	01
04	SECTION – 'A' SCOPE OF ENQUIRY	01
05	SECTION – 'B' PROJECT INFORMATION	04
06	SECTION – 'C' SPECIFIC TECHNICAL REQUIREMENT	07
	ANNEXURE-I BOQ-cum-PRICE SCHEDULE	03
	ANNEXURE-II LIST OF APPLICABLE STANDARDS	01
	ANNEXURE-III LOAD DUTY CYCLE FOR 220V DC SYSTEM	01
	ANNEXURE-IV ONE LINE DIAGRAM FOR 220V DC SYSTEM	01
	ANNEXURE-V ACCESSORIES	01
	ANNEXURE-VI LIST OF STANDARD DELIVERABLES	01
	ANNEXURE-VII NO. OF DRGS / DOCS REQUIRED	01
07	DATASHEET-'A' DC BATTERY	01
08	DATASHEET-'C' DC BATTERY	03
09	QUALITY PLAN	04

TOTAL NO. OF SHEETS = 33 (INCLUDING COVER/ SEPARATOR SHEETS)

(REFER INSTRUCTION NO. 1 OF 'INSTRUCTIONS TO BIDDERS')

**IT IS CONFIRMED THAT OUR TECHNICAL OFFER COMPLIES WITH THE SPECIFICATION IN TOTO, & THAT
THERE ARE NO TECHNICAL DEVIATIONS.**

BIDDER'S STAMP & SIGNATURE



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 2 OF 31

INSTRUCTIONS TO BIDDERS FOR PREPARING TECHNICAL OFFERS

1. In line with clause no. 10.1 of Section-C, Volume-II-B of the specification, two signed and stamped copies of the following shall be furnished by all bidders as technical offer:
 - a. Battery sizing calculation with respect to load duty cycle as per Annexure-III of Section-C to be provided along with supporting documents (capability / discharge curve, temperature correction factor, float charging factor & published technical catalogue) for considered factors.
 - b. Unpriced Price Schedule ("Annexure-I: BOQ cum Price Schedule", as enclosed with the specification) with bidder's signature and company stamp.
 - c. A copy of this sheet ("Instructions to Bidders for Preparing Technical Offer"), with bidder's signature and company stamp.
 - d. A copy of previous sheet ("List of Contents"), with bidder's signature and company stamp.
 - e. A copy of next sheet ("Deviation Schedule"), with "NO DEVIATION" and bidder's signature and company stamp.
 - f. A copy of sheet ("Data Sheet-A"), with required information and bidder's signature and company stamp.
 - g. List of O/M spares (Recommended) for 3 years of plant operation. (Unpriced)
2. No technical submittal except as stated above, such as copies of type test certificates, data Sheets, write-up, drawing, technical literature, etc. is required during tender stage. Any such submission, even if made, shall not be considered as part of offer.
3. Confirmations/ comments (if any) regarding delivery schedules shall be furnished as part of the commercial offer. Any reference elsewhere/ covering letter of technical offer shall not be considered by BHEL.
4. Any comments/ clarifications on technical/ inspection requirements furnished as part of bidder's covering letter shall not be considered by BHEL, and bidder's offer shall be construed to be in conformance with the specification.
5. Any changes made by the bidder in the price schedule with respect to the battery description/ quantities, notes etc. from those given in Annexure-I: BOQ cum Price Schedule shall not be considered (i.e., technical description, quantities, notes etc. as per specification shall prevail).
6. Bidder to note that wherever IS is mentioned equivalent IEC is also acceptable. In case of any technical requirement not covered by IEC, technical requirement as per IS shall prevail.
7. Deviations, if any should be brought out very clearly on deviation schedule enclosed with specification only. Otherwise it will be presumed that the bidder's offer is in line with what has been stated / asked for in this specification.

BIDDER'S STAMP & SIGNATURE



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 7 OF 31

DEVIATION SCHEDULE

SL. NO.	CLAUSE NO.	DEVIATION	REASONS FOR DEVIATION

It is certified that the offer is fully in conformance to the specification requirements except for the deviations, which are specifically brought out in the above prescribed Deviation Schedule.

Signature & seal of Bidder's authorized representative



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 8 OF 31

PREAMBLE

1.0 The Tender documents contains three (3) volumes. The bidder shall meet the requirements of all three volumes.

1.1 **VOLUME - I** **CONDITIONS OF CONTRACT**

This consists of four parts as below:-

Volume – IA This part contains Instructions to bidders for making bids to BHEL.

Volume – IB This part contains General Commercial Conditions of the Tender & includes provision that vender shall be responsible for the quality of item supplied by their sub-vendors.

Volume – IC This part contains Special Conditions of Contract.

Volume – ID This part contains Commercial conditions for Erection & Commissioning site work, as applicable.

1.2 **VOLUME – II** **TECHNICAL SPECIFICATION**

Technical requirements are stipulated in Volume – II, which comprises of:-

Volume – IIA General Technical Conditions.

Volume – IIB Technical Specification including Drawings, if any.

1.3 **VOLUME – IIB**

This volume is sub-divided in to following sections:-

Section – A This section outlines the Intent of Specification

Section – B This section provides “Project Information”.

Section – C This section indicates Technical Requirements specific to Contract.

Data sheet - A :- Specific data and other requirements pertaining to the equipments.

Data sheet – C :- Indicates data / documents to be furnished after the award of Contract as per agreed schedule by the vendor (as applicable)

Quality Plan



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 9 OF 31

SECTION - A

SCOPE OF ENQUIRY

- 1.0 This specification covers the design, manufacture, inspection and testing at manufacturer's works, proper packing and delivery to site of 220V DC Battery as mentioned in different sections of this specification for **2X660 MW SURATGARH STPS, STAGE-V, UNIT 7 & 8**.
- 2.0 It is not the intent to specify herein all the details of design & manufacture. However, the equipment shall conform in all respects to high standards of design engineering and workmanship and shall be capable of performing in continuous commercial operation up to bidder's guarantee.
- 3.0 The general terms and conditions, instructions to bidders and other attachment referred to elsewhere are hereby made part of the Technical Specification.
- 4.0 The bidders shall be responsible for and governed by all requirements stipulated hereinafter.
- 5.0 Bidders shall confirm total compliance to the specification without any deviations from the technical/ quality assurance requirements stipulated.
- 6.0 The documents shall be in English language and MKS system of units.



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 10 OF 31

SECTION – ‘B’

SPEC.NO. TCE.5750A-H-500-001	TATA CONSULTING ENGINEERS LIMITED		VOLUME II SECTION – B
	RRVUNL, 2 x 660 MW, Super-Critical TPS, Stage-V, Unit # 7 & 8 at Suratgarh, Rajasthan GENERAL PROJECT INFORMATION		SHEET 1 OF 3

1.0	Owner	Rajasthan Rajya Vidyut Utpadan Nigam Ltd., Jaipur
2.0	Consulting Engineer	TATA Consulting Engineers Ltd. 73/1, St. Marks Road, Bangalore – 560 001 Tel : 080 – 6622 6000 Fax : 080 – 22274874
3.0	Location of the plant	Prabat Nagar, Suratgarh Sriganganagar district, Rajasthan.
4.0	Latitude and longitude	Latitude : 29 deg. 10 min. N Longitude : 74 deg.01 min. E
5.0	Elevation above mean sea level	186 m (approximate)
6.0	Climatic conditions	
6.1	Temperatures : Monthly basis	
	Mean of daily max.	32.8 deg.C (in the month of May)
	Mean of daily min.	17.6 deg.C (in the month of Jan)
6.2	Temperatures : Annual basis	
	Mean of daily max.	32.3 deg.C
	Mean of daily min.	19.6 deg.C
	Highest temperature recorded	50 deg.C
	Lowest temperature recorded	(-) 2.8 deg.C
	Design Ambient Temperature for Electrical Equipment design	50 deg C
6.3	Relative humidity	Varies between 21% and 81%
6.4	Annual average rain fall	312 mm
6.5	Annual mean wind speed :	4 km / hr.
7.0	Wind load	

ISSUE R1

SPEC.NO. TCE.5750A-H-500-001	TATA CONSULTING ENGINEERS LIMITED		VOLUME II SECTION – B
	RRVUNL, 2 x 660 MW, Super-Critical TPS, Stage-V, Unit # 7 & 8 at Suratgarh, Rajasthan GENERAL PROJECT INFORMATION		SHEET 2 OF 3

	Calculations for wind effect shall be in accordance with IS:875-1987(Part-3) taking into account the following:		
	a) Basic wind speed = 47 m/sec		
	b) Factor K1 = 1.07		
	c) Category of terrain = Category 2		
	d) K3 – as per IS 875		
8.0	Seismic data (As per IS: 1893 latest issue)		
	a) Zone	Zone II	
	Designs & design coefficients shall be based on IS 1893:2002		
	Design condenser cooling water inlet temperature	33 Deg C	
9.0	Auxiliary power supply:		
	Auxiliary electrical equipment to be supplied against this specification shall be suitable for operation on the following system:		
	a)	For motors rated 160 kW and below.	415V AC, 3-phase, 3-wire effectively earthed.
	b)	For motors rated above 160 kW and up to 1500 kW	6600V AC, 3-phase, 3-wire, 50 Hz, non-effectively earthed
	c)	For motors rated above 1500kW	11000V AC, 3-phase, 3-wire, 50 Hz, non-effectively earthed
	d)	For motor control centres	415V AC, 3-phase, 3/4-wire effectively earthed.
	e)	DC motor starters, DC solenoids, DC alarm control and protection	220 V DC, 2-wire unearthed
	f)	AC control & protective devices	110 V 1 phase, 50Hz, 2 wire AC supply. The single phase 110V AC supply shall be derived by VENDOR by providing 415V / 110 V Control transformers of adequate rating with MCCB / MCB on both the primary and secondary sides.
	g)	Uninterrupted power supply	230 V, 1-phase, 50 Hz, 2-wire, AC

ISSUE R1

SPEC.NO. TCE.5750A-H-500-001	TATA CONSULTING ENGINEERS LIMITED		VOLUME II SECTION – B
	RRVUNL, 2 x 660 MW, Super-Critical TPS, Stage-V, Unit # 7 & 8 at Suratgarh, Rajasthan GENERAL PROJECT INFORMATION		SHEET 3 OF 3

		supply (For all instrumentation and control system equipment and solenoid valves)
--	--	---

g) Lighting fixtures and space heaters 240 V, 1 phase, 2 wire, 50Hz,solidly earthed system

h) Construction supply 415 V, 3 phase, 4 wire, 50Hz AC supply with neutral lead solidly earthed.

i) The above voltages may vary as follows :

All devices shall be suitable for continuous operation over the entire range of voltage and frequency indicated below without any change in their performance.

AC supply	Voltage variation $\pm 10\%$ Frequency variation $\pm 5\%$
DC supply	Combined voltage & frequency variation 10% Voltage variation +10% , -15%

j) For instrument and control system of steam generator and steam turbine generator. 230 V $\pm 5\%$ AC UPS, 1-phase, 50 Hz, 2-wire. The 24 V DC required for control system shall be generated from this UPS.

10.0 All the electrical equipment shall be designed for 50° C reference ambient temperature.

ISSUE
R1



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 11 OF 31

SECTION – C

SPECIFIC TECHNICAL REQUIREMENT

1.0 SCOPE OF ENQUIRY

This specification covers the design, manufacture, assembly, testing and inspection at vendor's/sub-vendor's works, packing and despatch to site of 220V DC batteries as described in the various sections of this specification. The batteries shall generally conform to IS / IEC. In this specification, as erection and commissioning is not included in vendor's scope, Vendor shall still not be absolved of his responsibility of establishing the correctness of equipment at site.

2.0 EQUIPMENT AND SERVICES TO BE FURNISHED BY THE BIDDER

The bidder shall supply the following equipment in accordance with the various sections of this specification. The BOQ cum Price Schedule is enclosed as Annexure-I.

3.0 SERVICES AND EQUIPMENT TO BE EXCLUDED

- A) Civil works like foundation and cable cellar, flooring of the battery room etc.
- B) Ventilation of battery and charger room.
- C) DCDB
- D) Power and control cables
- E) Erection of the equipment
- F) Battery charger, battery fuse box and discharge resistor panel

4.0 CODES AND STANDARDS

Unless otherwise specified, the latest revisions of codes/standards specified in Annexure-II enclosed are applicable and shall be referred to.

5.0 SCHEDULE OF PRICES – BOQ Cum Price Schedule For Unit Battery(Annexure-I A) , BOQ Cum Price Schedule For station Battery(Annexure-I B), BOQ Cum Price Schedule For River Water Battery(Annexure-I C) , BOQ Cum Price Schedule For O & M Spare(Annexure-I D) Shall Be Considered For Price Evaluation Purpose.

DELIVERY: Ex-works delivery of equipment shall be as per NIT.

6.0 SYSTEM CONCEPT

6.01 220V DC system is comprising of 2x100% batteries with individual redundant float cum boost charger (FCBC) and distribution board for control, protection,



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 12 OF 31

interlocking. Each side of DCDB will cater DC load duty cycle requirement as per Annexure-III of Section-C.

- 6.02 Battery and charger will be connected to DCDB as per Annexure-IV.
- 6.03 In case of failure of AC, battery will meet the DC load requirement. After restoration of power, the float charger will continue to supply the loads as well as trickle charge the battery. Under discharge condition, at a time only one battery will be put to boost charge.
- 6.03 The 220V batteries are sized considering emergency load cycle requirement of 600 minutes and design factors (as per Annexure-III).
- 6.04 The voltage at load terminal will not exceed the limits of +10% and -15% of nominal system voltage for 220V DC system.
- 6.05 Batteries and chargers shall be connected to DC distribution board through single cores cables for each pole. Battery terminals shall be made suitable for above cable.
- 6.06 The equipment will be located indoor but in a hot, humid and tropical atmosphere.
- 6.07 Necessary accessories required for maintenance and testing of batteries shall be supplied with each battery bank as per enclosed Annexure-V.

7.0 OTHER TECHNICAL REQUIREMENTS

7.1 Lead-Acid Batteries

- a) Batteries shall be stationery storage Lead Acid Plante high discharge type conforming to IS-1652 / IEC60896-11. The batteries shall meet the 'Load Duty Cycle' requirements under all site-operating conditions as specified.
- b) Containers:
Containers shall be made of transparent glass, robust, heat resistant, leak proof, non-absorbent, acid resistant, non-bulging type and free from flaws such as wrinkles, cracks, blisters, pinholes etc. Electrolyte level lines shall be marked on containers in case of translucent containers. The marking for the electrolyte level shall be for upper & lower limits. Container shall be SAN container closed/sealed lid type. Open type cells are not acceptable. Lid and sealing compound shall be non-cracking type. The container made of plastics shall be type tested as per IS-1146. All type tests shall be carried out for sealing compound as per IS-3116. The pole sealing arrangement shall be such that no acid particle gets entrapped due to acid creep as a result of capillary action and it shall be possible to remove and refix the sealing to carry out maintenance.



TECHNICAL SPECIFICATION FOR 220V DC BATTERY

2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 13 OF 31

c) Vent Plugs:

Vent plugs shall be provided in each cell. They shall be anti splash type, having more than one exit hole shall allow the gases to escape freely but shall prevent acid from coming out. The design shall be such that the water loss due to evaporation is kept to minimum. In addition the ventilator shall be easily removed from topping up the cells and of such dimensions that the syringe type hydrometer can be inserted into the vent to take electrolyte sample.

d) Plates:

The plates shall be designed for maximum durability during all service conditions including high rate of discharge and rapid fluctuation of load. The construction of plate shall be as per IS-1652 / IEC60896-11.

The separators shall maintain the electrical insulation between the plates and shall permit free flow of electrolyte. Separators shall be suitable for continuous immersion in the electrolyte without distortion. The positive and negative terminal posts shall be clearly marked.

e) Sediment Space:

Sufficient sediment space shall be provided so that cells will not have to be cleaned during normal life and prevent shorts within the cells.

f) Electrolyte:

The electrolyte shall be prepared from battery grade Sulphuric Acid conforming to IS-266 and distilled water conforming to IS-1069. The cells shall be shipped in dry uncharged condition and electrolyte shall be supplied separately in non-returnable containers. 10% extra electrolyte shall be furnished as extra fitting to cover spillage in transit or during erection.

g) Connectors and Fasteners:

Lead or lead coated copper connectors (or a better product) shall be used for connecting up adjacent cells and rows. Bolts, nuts, clamps and washers shall be lead coated with minimum thickness 0.025 mm to prevent corrosion. The thickness of lead coating shall be measured as per appendix-F of IS-6848. All the terminals and inter-cell connectors shall be fully insulated or shrouded. End take of connections from positive and negative poles of batteries shall be done through single core cable having stranded aluminium conductor and XLPE insulation. The bidder shall supply lead coated bent copper plate, tubular copper lugs, clamps, bolts, nuts, washers, etc. for termination of these cables on batteries. Suitable numbers of inter rack connectors shall be supplied by the bidder to suit the battery room layout during detailed engineering. Calculation for sizing of connectors and fasteners shall be furnished during detail engineering.

All connectors and lugs shall be capable of continuously carrying the 10 hours discharge current of respective batteries and through fault short circuit current,



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 14 OF 31

which the battery can produce and withstand for the period of one minute. The successful bidder shall furnish necessary sizing calculations to prove the compliance for the same at contract stage.

h) Battery Racks:

The batteries shall be supported on wooden/ metal racks properly treated for anti sulphuric acid resistance. The racks shall be free standing type mounted on porcelain / hard rubber / PVC pads insulators. The batteries racks and supports for cable termination shall be coated with three coats of anti-acid paint of approved shade. The nameplates, resistant to acid, for each cell shall be attached on the necessary racks.

Wherever racks are transported in dismantled conditions, match makings shall be provided to facilitate easy assembly.

i) Following information shall be indelibly marked on outside of each cell:

- Manufacturer's name and trade marks
- Country and year of manufacturer
- Manufacturer type designation
- AH capacity at 10 hour discharge rate
- Serial number

j) Positive and negative terminal posts shall be clearly and indelibly marked for easy identification.

k) Following minimum information shall be given on the instruction cards:

- Manufacturer's instructions for filling and initial charging of the battery together with starting and finishing charging rate
- Maintenance instructions
- Designation of cell in accordance with relevant standard
- Storing conditions of electrolyte

8.0 PERFORMANCE GUARANTEE

8.1 Bidders shall guarantee that battery offered shall meet the 'Load Duty Cycle' requirements as stipulated in this specification and as confirmed by them in technical data sheets. In case the performance of battery at site is not as per the performance guarantee, the bidder will have to replace the battery at site free of cost.

9.0 INSPECTIONS & TESTING

9.1 Offered equipment shall be of type test design. The bidder shall confirm compliance to quality plan enclosed with the specification, which is subject to RPCL approval and the inspection shall be carried out based on this approved Quality Plan (QP No. PE-QP-999-508-E002, Rev. 00).



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 15 OF 31

- 9.2 All acceptance and routine tests as per relevant standards shall be carried out by the manufacturer. Charges for all these routine and acceptance tests for all the materials shall be deemed to be included in the bid price.
- 9.3 Following type tests as per IS-1652 / IEC60896-11 to be conducted on battery
a. Capacity test and test for battery voltage during discharge.
- 9.4 The Capacity test and test for voltage on battery during discharge shall be carried out at site on completion of E&C and immediately prior to putting battery in service. Necessary testing equipment required for testing at site (including site visit) shall be arranged by bidder.
- 9.5 For all components / materials, for which type test reports have been asked as per relevant standard, such Type tests should have been carried out on identical components / materials. In absence of such type tests reports or in case such reports are not found to be meeting the specification/standards requirements, vendor shall conduct all such type tests without any commercial/delivery implication to BHEL according to the relevant standards and reports shall be submitted to the owner for approval. (Type test charges as per clause 9.6 shall not be applicable in such cases).
- 9.6 The bidder shall indicate cost of carrying out all the Type tests as specified in the specification. The charges for each of the Type tests shall be given separately in price schedule. These prices will be applicable in case a type test is required to be conducted by purchaser despite availability of satisfactory type test report as per clause 9.5 above.
- 9.7 All material used for the construction of the equipment / items shall be new and shall be in accordance with the requirements of this specification. Materials utilised shall be those, which have established themselves for use in such applications.
- 10.0 **DOCUMENTATION**
- 10.1 By all Bidders as technical offer:
- (i) Battery sizing calculation with respect to load duty cycle as per Annexure-III of Section-C to be provided along with supporting documents (capability / discharge curve, temperature correction factor, float charging factor & published technical catalogue) for considered factors.
 - (ii) Unpriced Price Schedule ("Annexure-I: BOQ cum Price Schedule", as enclosed with the specification) with bidder's signature and company stamp.
 - (iii) A copy of sheet "Instructions to Bidders for Preparing Technical Offer" with bidder's signature and company stamp.



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 16 OF 31

- (iv) A copy of sheet "List Of Contents" with bidder's signature and company stamp.
- (v) A copy of sheet "Deviation Schedule" with "NO DEVIATION" and bidder's signature and company stamp.
- (vi) A copy of sheet "Data Sheet-A" with required information and bidder's signature and company stamp.
- (vii) List of O/M spares (Recommended) for 3 years of plant operation.
(Unpriced)

10.2 Final documents to be submitted after award of contract shall be as given in Annexure-VI.

10.3 No. of prints to be submitted by vendor after award of contract shall be as specified under Annexure-VII.

10.4 Instruction Manuals

Instruction manuals for the installation, operation and maintenance of battery to be supplied shall be furnished at least two months before the date of despatch of equipment.

The installation and maintenance manual of battery shall contain the following:

- A) General description giving type and rating of various batteries.
- B) Technical data.
- C) Salient constructional details.
- D) Instruction to be followed on receipt at site.
- E) Instructions for foundations, if any.
- F) Erection procedures and checks (handling at site, erection, pre-commissioning).
- G) Procedure for filling of electrolyte.
- H) Commissioning procedures and site tests.
- I) Routine, periodic and preventive inspection and maintenance procedures.
- J) Safety rules.
- K) Possible faults, their causes and remedies.
- L) Copies of the type, acceptance and routine test certificates in bound volume.
- M) Catalogues, literature and drawings.
- N) Outline dimension drawings showing constructional features, relevant cross sectional views and earthing details, operator oriented description of equipment and accessories.



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 17 OF 31

O) Operating procedures, maintenance procedures & precautions to be taken during operation and maintenance work.

10.5 Bidder shall furnish field quality plan detailing out the specific quality control procedure covering receipt of material/equipment and handling at site, storage, erection, commissioning, post commissioning etc.

11.0 TOOLS AND TACKLE

Tools & tackle which are essential to facilitate assembly, adjustments, maintenance & dismantling of equipment shall be provided as part of equipment supplied. The above tools shall be supplied along with the initial consignment of equipment so as to be available prior to erection but may not be used for erection purposes.

12.0 BASIC DESIGN DOCUMENTS

'Basic Design Documents' cover: Battery data sheet, connector sizing calculation, Quality Plan, OGA for 220V battery, type test reports & type test procedure (if applicable) for battery.

13.0 AS-BUILT DRAWINGS

Though only supply of equipment is under bidder's scope, bidder may note that all as-built correction (as given by purchaser to vendor) shall have to be incorporated in the originals by the vendor and copies of the as-built corrected drawings / documents as per requirement shall be submitted by the vendor.

14.0 Statutory and regulatory requirements as per IE rule 1956 with amendment - 3 rule 1986, rules Nos. 35, 42, 50 & 51 shall be adhered to.

2X660 MW SURATGARH STPS, STAGE-V
ANNEXURE-I
BOQ CUM PRICE SCHEDULE(MAIN)

Sr. No.	Item code	Item Description	price	REMARK
MAIN ITEMS				
1.0		TOTAL PRICE OF ANNEXURE-I (A)		
2.0		TOTAL PRICE OF ANNEXURE-I (B)		
3.0		TOTAL PRICE OF ANNEXURE-I (C)		
4.0		TOTAL PRICE OF ANNEXURE-I (D)		
		TOTAL PRICE OF ALL ANNEXURE		

Sr. No.	Item code	Item Description	Unit	Quantity	Unit Price	Total price	Remarks
(A)	MAIN ITEMS						
1.0	508-14001-A	LEAD ACID PLANTE 220V UNIT BATTERY	Nos.	4			220V DC, AH capacity to be decided by bidder as per Annexure-III (UNIT BATTERY) of Section-C, 1.85 ECV, 108 cells, Lead-Acid Plante high discharge battery with 100% electrolyte +10% extra electrolyte, all accessories listed at 1.1, suitable cable termination arrangement and wooden/ metal properly treated for anti sulphuric acid resistance coated with 3 coats of anti-acid plant.
1.1		LIST OF ACCESSORIES WITH EACH BATTERY SET					Part of item 1.0
1.1.1		Hydrometer to measure specific gravity (in steps of 0.005)	No.	1			
1.1.2		Specific gravity correction scale.	No.	1			
1.1.3		Pocket thermometer	No.	1			
1.1.4		Acid resisting funnels	Nos.	2			
1.1.5		Acid resisting jugs of adequate capacity	No.	1			
1.1.6		Rubber aprons	No.	1			
1.1.7		Pair of Rubber hand gloves	No.	1			
1.1.8		Cell lifting straps	No.	1			
1.1.9		DC Voltmeter	No.	1			
1.1.10		+/- 3 volts DC voltmeter with suitable leads for measuring cell voltage	No.	1			
1.1.11		Cable clamps with fixing hardware	Lot	1			
1.1.12		PVC spill trays under the battery cells	set	1			
1.1.13		Set of Spanner	set	1			
1.1.14		Goggles (Industrial)	Nos.	2			
1.1.15		Battery Log book	Nos.	1			
1.1.16		Wall mounting type holder for hydrometer and thermometer	Set	1			
1.1.17		Set of intercell inter-tire and inter bank connectors as required for complete installation	set	1			
2.0	508-14013-A	MANDATORY SPARES					
2.1		Connectors with Nuts & Bolts		3%			
2.2		Vent plugs		3%			
2.3		Cell container empty	Nos.	4			
3.0	508-14010-A	E & C SPARES	Set	1			
3.1		Intercell connector	Nos.	5			
3.2		Vent plug	Nos.	5			
3.3		Gloves	Set	2			
4.0	508-14020-A	TYPE TEST	Lot	1			
4.1		Test for capacity & test for voltage during discharge (To be carried out at site on completion of E&C and immediately prior to putting battery in service)	Lot				
5.0	508-14007-A	Battery health monitoring system		8			
6.0	508-14016-A	SUPV. OF E&C	Set	2			1 Set refers to 2 No. Unit Battery.

TOTAL

Notes:

- 1) Cable Lugs at battery terminals shall be in bidder's scope & cable sizes shall be informed during detailed engineering.

Sr. No.	Item code	Item Description	Unit	Quantity	Unit Price	Total Price	Remarks
(A)	MAIN ITEMS						
1.0	508-14002-A	LEAD ACID PLANTE 220V STATION BATTERY	Nos.	2			220V DC, AH capacity to be decided by bidder as per Annexure-III (STATION BATTERY) of Section-C, 1.85 ECV, 108 cells, Lead-Acid Plante high discharge battery with 100% electrolyte +10% extra electrolyte, all accessories listed at 1.1, suitable cable termination arrangement and wooden/ metal properly treated for anti sulphuric acid resistance coated with 3 coats of anti-acid plant.
1.1		LIST OF ACCESSORIES WITH EACH BATTERY SET					Part of item 1.0
1.1.1		Hydrometer to measure specific gravity (in steps of 0.005)	No.	1			
1.1.2		Specific gravity correction scale.	No.	1			
1.1.3		Pocket thermometer	No.	1			
1.1.4		Acid resisting funnels	Nos.	2			
1.1.5		Acid resisting jugs of adequate capacity	No.	1			
1.1.6		Rubber aprons	No.	1			
1.1.7		Pair of Rubber hand gloves	No.	1			
1.1.8		Cell lifting straps	No.	1			
1.1.9		DC Voltmeter	No.	1			
1.1.10		+/- 3 volts DC voltmeter with suitable leads for measuring cell voltage	No.	1			
1.1.11		Cable clamps with fixing hardware	Lot	1			
1.1.12		PVC spill trays under the battery cells	set	1			
1.1.13		Set of Spanner	set	1			
1.1.14		Goggles (Industrial)	Nos.	2			
1.1.15		Battery Log book	Nos.	1			
1.1.16		Wall mounting type holder for hydrometer and thermometer	Set	1			
1.1.17		Set of intercell inter-tire and inter bank connectors as required for complete installation	set	1			
2.0	508-14013-A	MANDATORY SPARES					
2.1		Connectors with Nuts & Bolts		3%			
2.2		Vent plugs		3%			
2.3		Cell container empty	Nos.	4			
3.0	508-14010-A	E & C SPARES	Set	1			
3.1		Intercell connector	Nos.	5			
3.2		Vent plug	Nos.	5			
3.3		Gloves	Set	2			
4.0	508-14020-A	TYPE TEST	Lot	1			
4.1		Test for capacity & test for voltage during discharge (To be carried out at site on completion of E&C and immediately prior to putting battery in service)	Lot				
5.0	508-14008-A	Battery health monitoring system		2			
6.0	508-14016-A	SUPV. OF E&C	Set	2			1 Set refers to 2 no. of station Battery.

TOTAL

Notes:

- 1) Cable Lugs at battery terminals shall be in bidder's scope & cable sizes shall be informed during detailed engineering.

Sr. No.	Item code	Item Description	Unit	Quantity	Unit Price	Total Price	Remarks
(A)	MAIN ITEMS						
1.0	508-14003-A	LEAD ACID PLANTE 220V RIVER WATER BATTERY	Nos.	2			220V DC, AH capacity to be decided by bidder as per Annexure-III (RIVER WATER BATTERY) of Section-C, 1.85 ECV, 108 cells, Lead-Acid Plante high discharge battery with 100% electrolyte +10% extra electrolyte, all accessories listed at 1.1, suitable cable termination arrangement and wooden/metal properly treated for anti sulphuric acid resistance coated with 3 coats of anti-acid plant.
1.1		LIST OF ACCESSORIES WITH EACH BATTERY SET					
1.1.1		Hydrometer to measure specific gravity (in steps of 0.005)	No.	1			
1.1.2		Specific gravity correction scale.	No.	1			
1.1.3		Pocket thermometer	No.	1			
1.1.4		Acid resisting funnels	Nos.	2			
1.1.5		Acid resisting jugs of adequate capacity	No.	1			
1.1.6		Rubber aprons	No.	1			
1.1.7		Pair of Rubber hand gloves	No.	1			
1.1.8		Cell lifting straps	No.	1			
1.1.9		DC Voltmeter	No.	1			
1.1.10		+/- 3 volts DC voltmeter with suitable leads for measuring cell voltage	No.	1			
1.1.11		Cable clamps with fixing hardware	Lot	1			
1.1.12		PVC spill trays under the battery cells	set	1			
1.1.13		Set of Spanner	set	1			
1.1.14		Goggles (Industrial)	Nos.	2			
1.1.15		Battery Log book	Nos.	1			
1.1.16		Wall mounting type holder for hydrometer and thermometer	Set	1			
1.1.17		Set of intercell inter-tire and inter bank connectors as required for complete installation	set	1			
2.0	508-14013-A	MANDATORY SPARES					
2.1		Connectors with Nuts & Bolts		3%			
2.2		Vent plugs		3%			
2.3		Cell container empty	Nos.	4			
3.0	508-14010-A	E & C SPARES	Set	1			
3.1		Intercell connector	Nos.	5			
3.2		Vent plug	Nos.	5			
3.3		Gloves	Set	2			
4.0	508-14020-A	TYPE TEST	Lot	1			
4.1		Test for capacity & test for voltage during discharge (To be carried out at site on completion of E&C and immediately prior to putting battery in service)	Lot				
5.0	508-14009-A	Battery health monitoring system		2			
6.0	508-14016-A	SUPV. OF E&C	Set	1			1 Set refers to 2 no. of River water Battery.

TOTAL

Notes:

- 1) Cable Lugs at battery terminals shall be in bidder's scope & cable sizes shall be informed during detailed engineering.

2X660 MW SURATGARH STPS, STAGE-V
BOQ CUM PRICE SCHEDULE FOR O M SPARE

ANNEXURE-I (D)

Sr. No.	Item code	Item Description	Unit	Quantity	UNIT PRICE	TOTAL PRICE	Remarks
(A)	MAIN ITEMS						
1.0	508-14014-A	OPERATION & MAINTENANCE SPARES (RECOMMENDED) FOR 3 YEAR OF PLANT OPERATION	LOT	1			BIDDER TO FURNISH THE LIST.



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 18 OF 31

ANNEXURE-II

LIST OF APPLICABLE STANDARDS

- | | | |
|-----|---|-------------|
| 1. | STATIONERY LEAD ACID PLANTE BATTERY | IS 1652 |
| 2. | RECOMMENDED PRACTICE FOR SIZING LEAD ACID BATTERIES | IEEE 485 |
| 3. | SPECIFICATION FOR WATER FOR STORAGE BATTERIES | IS 1069 |
| 4. | SPECIFICATION FOR SULPHURIC ACID FOR LEAD ACID BATTERIES | IS 266 |
| 5. | RUBBER & PLASTIC CONTAINERS FOR LEAD ACID BATTERIES | IS 1146 |
| 6. | SYNTHETIC SEPARATORS FOR LEAD ACID BATTERIES | IS 6071 |
| 7. | SEALING COMPOUND FOR LEAD ACID BATTERIES | IS 3116 |
| 8. | METHODS OF TESTS FOR LEAD ACID BATTERIES | IS 8320 |
| 9. | SPECIFICATION FOR HIGH PERFORMANCE PLANTE'S CELLS | BS-6290 |
| 10. | ELECTRICAL VOCABULAR, PRIMARY CELLS AND BATTERIES. | IS: 1885 |
| 11. | LEAD-ACID BATTERIES FOR TRAIN LIGHTING & AIRCONDITIONING SERVICES | IS: 6848 |
| 12. | STATIONARY LEAD-ACID BATTERIES – VENTED TYPES – GENERAL REQUIREMENTS & METHODS OF TESTS | IEC60896-11 |
| 13. | INDIAN ELECTRICITY RULES & INDIAN ELECTRICITY ACTS | |

Note:

Vendor to note that wherever IS is mentioned equivalent IEC is also acceptable. In case of any technical requirement not covered by IEC, technical requirement as per IS shall prevail.



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B


SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 19 OF 31

ANNEXURE-III

(a) LOAD DUTY CYCLE FOR 220V DC SYSTEM (FOR UNIT BATTERY)



FACTORS TO BE CONSIDERED FOR BATTERY SIZING:

1. AGEING FACTOR : 1.0
2. DESIGN MARGIN : 1.10
3. MIN.ELECTROLYTIC TEMP. : 7.2 °C
4. END CELL VOLTAGE : 1.85V PER CELL
5. NUMBER OF CELLS : 108
6. TEMPERATURE CORRECTION FACTOR : AS PER Manufactures practice



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B


SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 20 OF 31

ANNEXURE-III

(b) LOAD DUTY CYCLE FOR 220V DC SYSTEM (FOR STATION BATTERY)



FACTORS TO BE CONSIDERED FOR BATTERY SIZING:

1. AGEING FACTOR : 1.0
2. DESIGN MARGIN : 1.10
3. MIN.ELECTROLYTIC TEMP. : 7.2° C
4. END CELL VOLTAGE : 1.85V PER CELL
5. NUMBER OF CELLS : 108
6. TEMPERATURE CORRECTION FACTOR : AS PER Manufactures practice



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B


SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 21 OF 31

ANNEXURE-III

(c) LOAD DUTY CYCLE FOR 220V DC SYSTEM (FOR RIVER WATER BATTERY)



FACTORS TO BE CONSIDERED FOR BATTERY SIZING:

1. AGEING FACTOR : 1.0
2. DESIGN MARGIN : 1.10
3. MIN.ELECTROLYTIC TEMP. : 7.2 °C
4. END CELL VOLTAGE : 1.85V PER CELL
5. NUMBER OF CELLS : 108
6. TEMPERATURE CORRECTION FACTOR : AS PER Manufactures practice



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B


SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 22 OF 31

ANNEXURE-IV

ONE LINE DIAGRAM FOR 220V UNIT DC SYSTEM





**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B


SECTION -

REVISION 0 DATE 10.05.2014

SHEET 23 OF 31

ANNEXURE-IV

ONE LINE DIAGRAM FOR 220V STATION DC SYSTEM





**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B


SECTION -

REVISION 0 DATE 10.05.2014

SHEET 24 OF 31

ANNEXURE-IV

ONE LINE DIAGRAM FOR 220V RIVER WATER DC SYSTEM





**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 25 OF 31

ANNEXURE-V

ACCESSORIES

Following accessories shall be provided for each battery bank:

S no	Name of accessory	QTY (in Nos.)
1	Hydrometer to measure specific gravity (in steps of 0.005)	1 No.
2	Specific gravity correction scale.	1 No.
3	Pocket thermometer	1 No.
4	Acid resisting funnels	2 Nos.
5	Acid resisting jugs of adequate capacity	1 No.
6	Rubber aprons	1 No.
7	Pair of Rubber hand gloves	1 No.
8	Cell lifting straps	1 No.
9	DC Voltmeter	1 No.
10	+/- 3 volts DC voltmeter with suitable leads for measuring cell voltage	1 Set
11	Cable clamps with fixing hardware	1 Set
12	PVC spill trays under the battery cells	1 Set
13	Set of Spanner	1 set
14	Goggles (Industrial)	2 Nos.
15	Battery Log book	1 No.
16	Wall mounting type holder for hydrometer and thermometer	1 Set
17	Set of intercell inter-tire and inter bank connectors as required for complete installation	1 set



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 26 OF 31

ANNEXURE-VI

LIST OF STANDARD DELIVERABLES

S. No.	DOCUMENT TITLE	DWG. / DOCUMENT No.
1	Data Sheet for battery	PE-V0-362-508-E201
2	Battery sizing calculation (Including battery catalogues, curves etc)	PE-V0-362-508-E202
3	Fault calculation & Connector sizing calculation	PE-V0-362-508-E203
4	General Arrangement drawing for Battery	PE-V0-362-508-E204
5	Bill of Material for the battery	PE-V0-362-508-E205
6	List of Mandatory Spares for battery	PE-V0-362-508-E206
7	O & M manual for battery	PE-V0-362-508-E207
8	Field Quality Plan for battery	PE-V0-362-508-E208
9	Type test reports for the battery	PE-V0-362-508-E209
10	Cable Termination arrangement for battery terminal	PE-V0-362-508-E210
11	Quality Plan for battery	PE-QP-999-508-E002



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 27 OF 31

DATASHEET -A

LEAD ACID PLANTE BATTERY

- | | | | |
|-----|---|---|--|
| 1. | Rated voltage (V) | : | 220V DC |
| 2. | Type of Battery | : | Lead Acid Plante
high discharge |
| 3. | Design Ambient | : | 50°C |
| 4. | Min Electrolyte temp. | : | 7.2°C |
| 5. | Cell Container | : | Transparent SAN |
| 6. | DC System Earthing | : | Unearthed |
| 7. | Conforming to | : | IEEE / IEC / IS standards |
| 8. | No. of cells & End cell voltage | : | 108 Nos.; 1.85V |
| 9. | Nominal Float voltage (V) | : | 2.25 V/cell |
| 10. | Boost voltage (Maximum)
(V) | : | Bidder to furnish the detail
along with offer |
| 11. | AH Capacity of battery at
27°C | : | Bidder to furnish quoted AH
capacity and battery sizing
calculation along with offer for
unit, station, river water |
| 12. | Arrangement of batteries
on racks | : | Single tier /Double Tier
as per IS |
| 13. | Connection from battery
to Charger (for Unit Battery) | : | 3- 1CX300sqmm (Cu)/ pole
(EPR insulated FS cable)
(Tentative Size) |
| 14. | Connection from battery
to Charger (for Station Battery) | : | 2-1CX300sqmm (Cu)/ Pole
(EPR insulated FS cable)
(Tentative Size) |
| 15. | Connection from battery
to Charger (for River Water
Battery) | : | 2-1CX150sqmm (Cu)/ Pole
(EPR insulated FS cable)
(Tentative Size) |



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 28 OF 31

Notes:

1. Bidder shall furnish following along with offer:

- i) Battery capability / discharge curve.
- ii) Battery sizing calculation
- iv) Indicate value at sl. No. 10 & 11 above.

2. Bidders stand guarantee that the rating offered at S. No. 11 shall meet 'Load Duty Cycle' **as per Annexure-III of specification.**



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 | DATE 10.05.2014

SHEET 29 OF 31

DATA SHEET -C

S. No.	PARAMETER	UNIT	VALUE
1.0	Make and Type		
2.0	AH capacity at 27° C and end voltage		
2.1	At 10 Hr discharge rate	AH	
2.2	At 1 Hr discharge rate	AH	
3.0	Battery Discharge current		
3.1	At one minute rate	Amp	
3.2	At 30 minutes rate	Amp	
3.3	At 30 minutes rate at end voltage	Amp	
3.4	At 60 minutes rate	Amp	
3.5	At 60 minutes rate at end voltage	Amp	
4.0	Types of plates		
4.1	Negative plates		
4.2	Positive plates		
5.0	Method of connection between cells		
6.0	Voltage per cell at the end of charge at the finishing rate	V	
7.0	Recommended Trickle charge current	Amp	
8.0	Type and material of separators		
9.0	Material of container		
10.0	Type of container		
11.0	Internal resistance of cells	Ohms	
12.0	Total resistance of connectors	Ohms	
13.0	Insulator Material for		
13.1	Cells		
13.2	Racks		
14.0	Average life	Years	
15.0	Recommended boost charger rating for		
15.1	Charging in 8 hours	Amp	



TECHNICAL SPECIFICATION FOR 220V DC BATTERY

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001

VOLUME II B

SECTION -

REVISION 0 DATE 10.05.2014

SHEET 30 OF 31

15.2	Charging in 10 hours	Amp	
S. No.	PARAMETER	UNIT	VALUE
16.0	Allowable ripple content acceptable to battery (r.m.s)	%	
17.0	Hydrogen evaluation		
18.0	Cell designation in accordance with IS: 1651/1652		
19.0	Applicable standard		
20.0	Whether battery performance curve and calculation for capacities enclosed		
21.0	Recommended Maximum period of storage of Electrolyte before first charge		
22.0	Amount and specific gravity of electrolyte per cell required for first filling at 27° C		
23.0	Recommended specific gravity of electrolyte at 27° C		
23.1	When fully charged		
23.2	When fully discharged		
24.0	Container dimensions	(L X B X H)mm	
25.0	Distance between centres of cells when erected	Mm	
26.0	Terminal connectors		
26.1	Type		
26.2	Material		
27.0	Battery Racks		
27.1	Type & Material		
27.2	Outline dimensions	(L X B X H) mm	
27.3	Net weight	Kg	
28.0	Weight per cell	Kg	
28.1	Net dry weight	Kg	
28.2	Net weight with electrolyte	Kg	
29.0	Total shipping weight of one battery unit (without electrolyte)	Kg	
30.0	Taps provided at cell no.		
31.0	Connection from battery to charger (busbar/ cable)		
32.0	Recommended size of (busbar/ cable)		



**TECHNICAL SPECIFICATION FOR
220V DC BATTERY**

**2X660 MW SURATGARH STPS, STAGE-V,
UNIT- 7 & 8**

SPECIFICATION NO. PE-TS-392-508-E001


VOLUME II B

SECTION -


REVISION 0 DATE 10.05.2014

SHEET 31 OF 31


33.0	Whether backup calculation furnished		
34.0	Cable lugs at battery terminals of suitable size		

		QUALITY PLAN		CUSTOMER : RRVUNL		PROJECT: 2X660 MW SURATGARH STPS		SPECIFICATION NO. PE-TS-392-508-E001				
				BIDDER/ : VENDOR		TITLE 220V DC BATTERY		SPECIFICATION TS FOR 220V DC BATTERY				
		SHEET 1 OF 3		SYSTEM		ITEM : LEAD ACID BATTERY		DOC. NO.				
SL. NO.	COMPONENT/ OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
1	2	3	4	5	6	7	8	9	P	W	V	11
1.0	RAW MATERIALS & BOUGHT OUT ITEMS											
1.1	(Pure Lead for Pos. plate, Lead Alloy for Neg. plate & Sulphuric acid)	Chemical	MA	Chemical Analysis	Random Sample	IS:1652, IS:266, IS:1069 & MFR's Std.	IS:1652, IS:266, IS:1069 & MFR's Std.	Test Cert.	3/2	-	1	
1.2	SEPARATOR											
a)	Visual	Visual	MA	Visual	Random Sample	IS:1652 & MFR's Std.	IS:1652 & MFR's Std.	Test Cert.	3/2	-	1	
b)	Physical	Physical		Physical	-do-	-do-	-do-	-do-	3/2	-	1	
c)	Chemical	Chemical		Chemical	-do-	(For Synthetic IS : 6071)	(For Synthetic IS : 6071)	-do-	3/2	-	1	
d)	Electrical Resistance Test	Electrical		Electrical	-do-	-do-	-do-	-do-	3/2	-	1	
e)	Acceptance test Dimension, Volume Porosity, Wettability of separator	Test		As per Standard	-do-	-do-	-do-	-do-	3/2	-	1	
1.3	TERMINAL POST											
a)	Dimensional Conformance	Visual	MA	Visual	Random Sample	IS:1652, IS:8320 & MFR's Std.	IS:1652, IS:8320 & MFR's Std.	Test Cert.	3/2	-	1	
b)	Material Conformance	Chemical	CR	Chemical	-do-	-do-	-do-	-do-	3/2	-	1	
c)	Thread size depth & chamfer	Physical	MA	Measurement	-do-	-do-	-do-	-do-	3/2	-	1	
d)	Surface finish & defects	Visual	MA	-do-	100%	-do-	-do-	-do-	3/2	-	1	
e)	Plating Quality	Thickness	CR	-do-	Random Sample	-do-	-do-	-do-	3/2	-	1	
BHEL			PARTICULARS		BIDDER/ VENDOR							
			NAME									
			SIGNATURE									
			DATE					BIDDER'S/ VENDORS COMPANY SEAL				

LEGEND : 1 - BHEL/ CUSTOMER 2 - VENDOR 3 - SUB- VENDOR P - PERFORM W - WITNESS V - VERIFICATION

		QUALITY PLAN SHEET 2 OF 3		CUSTOMER : RRVUNL		PROJECT: 2X660 MW SURATGARH STPS		SPECIFICATION NO. PE-TS-392-508-E001				
				BIDDER/ :		TITLE 220V DC BATTERY		SPECIFICATION TS FOR 220V DC BATTERY				
				VENDOR		STANDARD QUALITY PLAN NO.- PE-QP-999-508-E002, REV.0		TITLE				
		SYSTEM		ITEM : LEAD ACID BATTERY		DOC. NO.						
SL. NO.	COMPONENT/ OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.4	CONNECTOR											
a)	Dimension	Dimension	MA	Measurement	Random Sample	IS:1652, IS:6848 & Appd. Drg./Doc.	IS:1652, IS:6848 & Appd. Drg./Doc.	Test Cert.	3/2	-	1	<i># Vent cap shall be easily removed from topping up the cells and of such dimensions that the syringe type hydrometer can be inserted into vent to take electrolyte sample.</i>
b)	Thickness of lead coating	Visual		Visual	-do-	-do-	-do-	-do-	3/2	-	1	
1.5	VENT CAP											
a)	Dimensional Conformance	Dimension	MA	Measurement	-do-	Refer Remarks#	Refer Remarks#	-do-	3/2	-	1	
1.6	CONTAINER											
a)	Verification Constructional requirement	Visual	MA	Visual	Sample Plan as per IS:1146	IS:1652, IS:1146, IS:8320	IS:1652, IS:1146, IS:8320	Test Cert.	3/2	-	1	
b)	Verification of Markings	Visual	MA	-do-	-do-	-do-	-do-	-do-	3/2	-	1	
c)	High Voltage Test	Electrical	MA	-do-	-do-	-do-	-do-	-do-	3/2	-	1	
d)	Drops Ball Test	Mechanical	MA	-do-	-do-	-do-	-do-	-do-	3/2	-	1	
e)	Plastic Yield Test	-do-	MA	-do-	-do-	-do-	-do-	-do-	3/2	-	1	
f)	Acid Resistance Test	Chemical	MA	-do-	-do-	-do-	-do-	-do-	3/2	-	1	
g)	Hydraulic thrust endurance test	Physical	MA	-do-	-do-	-do-	-do-	-do-	3/2	-	1	
2.0	FINISHED BATTERY	Routine Test	CR	Elec. & Meas.	100%	IS:1652 & IS:8320	IS:1652 & IS:8320	Test Cert.	3/2	-	1	
3.0	FINAL INSPECTION											
3.1	Type Test #											<i># Conduction of Type Tests from S.No. (d) to (g) shall be as per Annexure-A enclosed.</i>
a)	Verification Constructional requirement	Visual	MA	Visual	Sample Plan as per IS: 8320	IS:1652	IS:1652	Inspection Report	3/2	1	-	
b)	Verification of Markings	Dimension	MA	Measurement	-do-	-do-	-do-	-do-	3/2	1	-	
c)	Verification of Dimensions	-do-	MA	-do-	-do-	-do-	-do-	-do-	3/2	1	-	
d)	Test for Capacity & Voltage during discharge	Test	CR	As per IS: 1652	-do-	-do-	-do-	-do-	3/2	1	-	
BHEL			PARTICULARS		BIDDER/ VENDOR							
			NAME									
			SIGNATURE									
			DATE					BIDDER'S/ VENDORS COMPANY SEAL				

LEGEND : 1 - BHEL/ CUSTOMER 2 - VENDOR 3 - SUB- VENDOR P - PERFORM W - WITNESS V - VERIFICATION

		QUALITY PLAN		CUSTOMER : RRVUNL		PROJECT: 2X660 MW SURATGARH STPS		SPECIFICATION NO. PE-TS-392-508-E001					
				BIDDER/ VENDOR :		TITLE 220V DC BATTERY		SPECIFICATION TITLE TS FOR 220V DC BATTERY					
		SHEET 3 OF 3		SYSTEM		ITEM : LEAD ACID BATTERY		DOC. NO.					
SL. NO.	COMPONENT/ OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS	
1	2	3	4	5	6	7	8	9	10	P	W	V	11
e)	AH & WH efficiency Test	-do-	CR	As per IS:1652	Sample Plan as per IS:8320	IS:1652	IS:1652	Inspection Report	3/2	1	-		
f)	Retension of Charge	-do-	CR	-do-	-do-	-do-	-do-	-do-	3/2	1	-		
g)	Endurance Test	-do-	CR	-do-	-do-	-do-	-do-	-do-	3/2	1	-		
3.2 Acceptance Test													
a)	Verification of Markings	Visual	MA	Visual	Sample Plan as per IS: 8320	IS:1652	IS:1652	Inspection Report	3/2	1	-		
b)	Verification of Dimensions	Dimension	MA	Measurement	-do-	-do-	-do-	-do-	3/2	1	-		
c)	Test for Capacity	Capacity	CR	As per IS: 1652	-do-	-do-	-do-	-do-	3/2	1	-		
d)	Test for Voltage during discharge	Voltage during discharge	CR	-do-	-do-	-do-	-do-	-do-	3/2	1	-		
4.0	ACCESSORIES	Visual & Dimension	MA	Visual	100%	Appd. Drg./Doc.	Appd. Drg./Doc.	-do-	2	1	-		
5.0	CABLE LUGS	Visual	MA	Visual	100%	Appd. DataSheet	Appd. DataSheet	-do-	2	1	-		
<p>NOTE:- Wherever IS is mentioned equivalent IEC is also acceptable. In case of any technical requirement not covered by IEC, technical requirement as per IS shall prevail.</p>													
BHEL			PARTICULARS			BIDDER/ VENDOR			BIDDER'S/ VENDORS COMPANY SEAL				
			NAME										
			SIGNATURE										
			DATE										

LEGEND : 1 - BHEL/ CUSTOMER 2 - VENDOR 3 - SUB- VENDOR P - PERFORM W - WITNESS V - VERIFICATION

ANNEXURE-A

QUALITY PLAN

STANDARD QP NO. : PE-QP-999-508-E002, REV. 0

LIST OF TYPE TEST FOR LEAD ACID BATTERY

S No	Test	Type test description	Referred standard	Test to be specifically conducted (Yes/No)	BHEL/Customer's approval Req. on test certificate (Yes/No)
1	Type Test	• Test for Capacity & Voltage during discharge	IS:1652	Yes	Yes
		• AH & WH efficiency Test	IS:1652	No	Yes
		• Retention of Charge	IS:1652	No	Yes
		• Endurance Test	IS:1652	No	Yes