





1. MATERIAL & TEST:- AS PER IS10192/82, Gr. 'EP-3'.
2. GLASS FIBRE REINFORCEMENT-CONTINUOUS CLASS 'E'.
3. GLASS FIBRE ROVING 30 OR 60 ENDS.
4. RESIN EPOXY.
5. RING TO BE MOULDED IN STEEL MOULDS TO ACHIEVE DIMENSIONAL CONSISTANCY.
6. RING TO BE REMOVED FROM MOLD AFTER COLD SET (24 HRS.) AT ROOM TEMPERATURE.
7. BRACKETS TO BE DE-BURRED & FINISH BLACKOXIDIZED.

INVENTORY NO.	SIGN. & DATE	REF. DRG. NO.
---------------	--------------	---------------




IT.-005
SUPPORT CLAMP FOR NON
CONNECTION OVERHANG

[illegible][illegible]

ADDITIONAL INFORMATION	TYPE OF PRODUCT OR
REF. DRG. NO. 31WD 096.167	NAME OF CUSTOMER/PROJECT
STATUS OF DRAWING	6FRA-6068

DISTRIBUTION OF PRINTS		BPHARAT HEAVY ELECTRICALS LTD.		NO. OF VAR.
TME - 1	TNX - 1	NAME	DATE	
TXM - 3		SDB	05.06.21	
		AJ/PT	05.06.21	
		AJ/PT	05.06.21	00

DEPT. TME	UNTOOL. DIMS. GR.		SCALE	WEIGHT(K.G.)	REF. TO ASSY.DRG.		ITEM NO	NO.OF
CODE	"W"		NTS	NA	3 445 33 64 053		001 TO 005	ITEM
405	-							008
TITLE					REV.			
ACCESSORIES OF 3 PHASE					DRAWING NO.			
STATOR CHAMBER					3 445 31 64 058			
SHT. NO. 01		NO. OF SHT.		01				