



Ref: E-5632/2017/CORRIGENDUM/02

Date: 19/06/2017

DUE DATE
28/06/2017
14:00 (IST)

Our Ref:

- (i) Enq No.:- E-5632/2017 dated 01/06/2017
(ii) E-5632/2017/CORRIGENDUM/02 dated 12/06/2017

Subject: Technical Clarification and due date extension for above referred tender of DC Ni-Cd Battery of 2X660 MW ENNORE SEZ

Please note following:-

1. Earth leakage detector, as mentioned in Cl. 5.10, is considered in DCDB and thus is not in scope of subject tender.
2. The due date for bid submission (Part 1 and Part II) of subject tender has been extended up to 28/06/2017 by 14:00 HRS IST.

Thanking You

With regards
For & on behalf of BHEL

(AKASH VERMA)
Sr. ENGINEER/ PGII-2
PEM, BHEL, Noida