

Qualifying criteria (PQR) for Vendors

PRESSURE TRANSMITTERS

1. Vendor/Authorized dealer/Agent should have supplied similar type of pressure Transmitter in Hydro Power Station/ any other industry with following parameter in last 5 years (from Tender opening date Part-I).
 - i) Range: 0 to 16 kg/cm² or more
 - ii) Accuracy: $\pm 0.1\%$ or better

Vendor shall furnish unpriced PO copy and Delivery challan/invoice/ with approved drawing/ Bill of Material / Data Sheet or any other relevant documentary evidence as proof of supplying Pressure Transmitter with above parameters.

2. In case a vendor who is not an OEM is submitting offer, vendor shall submit authorization from OEM.
3. The OEM of Pressure Transmitter should have ISO Certificate

Nitesh Kumar
Mgr/MHX
07552503235