

# PRE-QUALIFYING (PQ) CRITERIA FOR VENDORS

P.I. NO.: – 241515356

ITEM DESCRIPTION: – LEVEL CONTROLLER FOR TGB AND PP SET (CAPACITANCE TYPE)

PROJECT: – KALWAKURTHY LIS STAGE-1

- 1) Vendor / OEM should have supplied capacitance type level controller for level switching in oil application in any Hydro Power Station / any other industry in India or abroad with following parameters in last 5 years (from tender opening date Part-1).

- (a) Probe length of level controller for level switching: **350 mm or more.**  
(b) Accuracy:  $\pm 0.5$  % or better.

Vendor shall furnish unpriced PO copy and Delivery Challan / Invoice with Approved Drawing / Bill of Material / Data Sheet or any other relevant documentary evidence as proof of supplying capacitance type level controller with above parameters.

- 2) The Vendor should be authorized dealer of offered capacitance type level controller and submit the authorization letter from OEM. It is not applicable for OEM.
- 3) The OEM of capacitance type level controller should have ISO certificate.


**Note:** Vendors are required to submit documentary evidence to prove the above qualifying criteria along with the bid /offer.



अमित पाण्डेय/AMIT PANDEY  
उप महाप्रबंधक / Dy. General Manager  
एच.पी.ई. विभाग / H.P.E. Division  
बी.एच.ई.एल., भोपाल / BHEL, BHOPAL



20.01.2022  
विशाल कुमार नामदेव / V.K. NAMDHE  
वरिष्ठ प्रबंधक / Senior Manager  
एच.पी.ई. विभाग / HPE Division  
बी.एच.ई.एल., भोपाल / BHEL, BHOPAL



मनीष साहू / MANISH SAHU  
वरिष्ठ उप महाप्रबंधक / Sr. Dy. General Manager  
एच.पी.ई. विभाग / HPE Division  
बी.एच.ई.एल., भोपाल / BHEL, BHOPAL