

PRE-QUALIFYING (PQ) CRITERIA FOR VENDORS FOR PI NO.
241516862

PROJECT – RMU OF KUTTIYADI HEP

1. Vendor (OEM/Authorized dealer) should have supplied *Refrigerated type LP air dryer* similar or higher size with respect to airflow capacity (36 CFM or more) at pressure (7 Kg/Cm² or more) as mentioned in the specification. Vendor (OEM/Authorized dealer) shall furnish unpriced copy of at least one purchase order and documentary evidence of fulfilling the criteria.
2. Vendor (OEM/Authorized dealer) shall have to submit undertaking regarding availability of test setup / facilities for testing of LP Air dryers as per our specification at OEM works.
3. In case a vendor who is not an OEM is submitting offer, vendor shall submit authorization from OEM. It is not applicable for OEMs.
4. Vendor (OEM/Authorized dealer) should have after sales service facility at OEM works in India for any servicing / rectification required.


दलपत भोरणा / DALPAT BORANA
प्रबंधक (अभियंता) / Manager (Design)
एच.पी.ई. विभाग / H.P.E. Division
बी.एच.ई.एल., भोपाल / BHEL, BHOPAL


अमित पाण्डेय / AMIT PANDEY
उप महाप्रबंधक / Dy. General Manager
एच.पी.ई. विभाग / H.P.E. Division
बी.एच.ई.एल., भोपाल / BHEL, BHOPAL


मनीष साहू / MANISH SAHU
वरिष्ठ उप महाप्रबंधक / Sr.Dy. General Manager
एच.पी.ई. विभाग / H.P.E. Division
बी.एच.ई.एल., भोपाल / BHEL, BHOPAL