

PRE-QUALIFYING (PQ) CRITERIA FOR VENDORS**PI NO. 241516461 REV.00****PROJECT – ARUN-III**

- 1) Vendor (OEM / Authorized dealer) should have supplied similar type Position feedback device [Magnetostrictive type of sensor (MLDT)] in Hydro Power Station / any other industry with following parameters in last 5 years (from tender opening date Part-1).

- (a) Active electric stroke: 180 mm
(b) Accuracy: 0.05% of FS

Vendor shall furnish unpriced PO copy and Delivery Challan / Invoice with Approved document (Drawing / Bill of Material / Data Sheet) or any other relevant documentary evidence as proof of supplying Position type feedback device [Magnetostrictive type of sensor (MLDT)] with above parameters.

- 2) The Vendor should be authorized dealer of offered Position type feedback device [Magnetostrictive type of sensor (MLDT)] and submit the authorization letter from OEM. It is not applicable for OEM.
- 3) The OEM of Position type feedback device [Magnetostrictive type of sensor (MLDT)] should have ISO certificate.

Sh. Prabhat
शिव प्रभात सिंह / SHIV PRABHAT SINGH
प्रबंधक / Manager
एच पी ई. विभाग / H.P.E. Division
बी.एच.ई.एल., भोपाल/BHEL, Bhopal

Yatendra Singh
Yatendra Singh
HPE-Gov
BHEL Bhopal.

30.03.22
विशाल कुमार नामदेव / V.K. NAMDEO
वरिष्ठ प्रबंधक / Senior Manager
एच पी ई. विभाग/HPE Division
बी.एच.ई.एल., भोपाल/BHEL, BHOPAL

Amit
अमित पाण्डेय/AMIT PANDEY
उप महाप्रबंधक / Dy. General Manager
एच.पी.ई. विभाग / H.P.E. Division
बी.एच.ई.एल., भोपाल/BHEL, BHOPAL