

PRE-QUALIFYING (PQ) CRITERIA FOR VENDORS

P.I. NO.: – 241526464

ITEM DESCRIPTION: – CONDUCTIVITY TYPE LEVEL CONTROLLER FOR TURBINE TOP COVER


PROJECT: – ARUN-III

- 1) Vendor should have supplied conductivity type level controller for level switching in water application in any Hydro Power Station / any other industry in India or abroad with following parameters in last 5 years (from tender opening date Part-1).
 - (a) Probe length of level controller for level switching: **100 mm or more**
 - (b) Type of Level probe = 3 in 1 or more.

Vendor shall furnish unpriced PO copy and Delivery Challan / Invoice with Approved Drawing / Bill of Material / Data Sheet or any other relevant documentary evidence as proof of supplying conductivity type level controller with above parameters.

- 2) The Vendor should be authorized dealer of offered conductivity type level controller and submit the authorization letter from OEM. It is not applicable for OEM.
- 3) The OEM of conductivity type level controller should have ISO certificate.

Note: Vendors are required to submit documentary evidence to prove the above qualifying criteria along with the bid /offer.


विशाल कुमार भास्कर/V.K. BHASKAR
वरिष्ठ प्रबंधक / Senior Manager
एच पी ई विभाग/HPE Division
बी.एच.ई.एल., भोपाल/BHEL, BHOPAL