

PRE-QUALIFYING (PQ) CRITERIA FOR VENDORS

P.I. NO.: – 241525379

ITEM DESCRIPTION: – LEVEL CONTROLLER FOR TGB AND PP SET (CAPACITANCE TYPE)

PROJECT: – NEEPCO KHANDONG (1 x 25 MW)


- 1) Vendor (Authorized dealer / OEM) should have supplied capacitance type level controller for level switching in oil application in any Hydro Power Station / any other industry in India or abroad with following parameters in last 5 years (from tender opening date Part-1).


- (a) Probe length of level controller for level switching: **303 mm or more.**
 (b) Accuracy: **±0.5% or better.**


Vendor shall furnish unpriced PO copy and Delivery Challan / Invoice with Approved Drawing / Bill of Material / Data Sheet or any other relevant documentary evidence as proof of supplying capacitance type level controller with above parameters.


- 2) The Vendor should be authorized dealer of offered capacitance type level controller and submit the authorization letter from OEM. It is not applicable for OEM.
- 3) The OEM of capacitance type level controller should have ISO certificate.

Note: Vendors are required to submit documentary evidence to prove the above qualifying criteria along with the bid /offer.


 दलपत बोरणा/DALPAT BORANA
 प्रबंधक (अभिकल्प)/Manager (Design)
 एच.पी.ई. विभाग/H.P.E. Division
 बी.एच.ई.एल., भोपाल/BHEL, BHOPAL


 विशाल कुमार नामदेव/V.K. NAMDEO
 वरिष्ठ प्रबंधक / Senior Manager
 एच.पी.ई. विभाग/HPE Division
 बी.एच.ई.एल., भोपाल/BHEL, BHOPAL


 मनीष साहू/MANISH SAHU
 वरिष्ठ महाप्रबंधक/Sr.Dy.General Manager
 एच.पी.ई. विभाग/HPE Division
 बी.एच.ई.एल., भोपाल/BHEL, BHOPAL


 अमित पाण्डेय/AMIT PANDEY
 उपा महाप्रबंधक / Dy. General Manager
 एच.पी.ई. विभाग/H.P.E. Division
 बी.एच.ई.एल., भोपाल/BHEL, BHOPAL